

## Article

# Modeling the Supply of Renewable Electricity to Metropolitan Regions in China

Mengzhu Xiao , Manuel Wetzel , Thomas Pregger , Sonja Simon  and Yvonne Scholz

German Aerospace Center (DLR), Institute of Engineering Thermodynamics, Department of Energy Systems Analysis, Pfaffenwaldring 38-40, 70569 Stuttgart, Germany; Manuel.Wetzel@dlr.de (M.W.); Thomas.Pregger@dlr.de (T.P.); Sonja.Simon@dlr.de (S.S.); Yvonne.Scholz@dlr.de (Y.S.)

\* Correspondence: Mengzhu.Xiao@dlr.de

Received: 8 May 2020; Accepted: 9 June 2020; Published: 12 June 2020




**Abstract:** The accelerated urbanization and industrialization in China is leading to major challenges due to rising energy demand and emissions. Cities in particular play an important role in the decision-making and implementation processes for the energy transition. However, they often have only limited local energy potential and are heavily dependent on supply regions. We therefore assess how a predominantly renewable power supply can be implemented based on the availability of local or imported renewable resources. We present a case study in which an advanced energy system model is parametrized and applied to address questions which are relevant to the transformation of the energy system in China. The model is capable of simultaneously optimizing investment decisions and hourly power balances of a scenario year, taking into account different storage technologies, regional power exchange and policy constraints such as carbon cap, carbon price and renewable portfolio standards. The study takes the Beijing-Tianjin-Hebei metropolitan region with Inner Mongolia as a supply region—considered as exemplary regions characterized by heterogeneous infrastructures, resources and consumption—as its model. Starting from a context-related normative energy scenario, we analyze a possible future electricity system under various assumptions using the Renewable Energy Mix (REMIX) energy system model developed at the DLR (German Aerospace Center). Depending on the estimated potentials of renewable energies, technology costs and the projected electricity demand, the metropolitan region is mainly supplied with imported wind and solar power. A sensitivity analysis considers installed capacities, annual generation, CO<sub>2</sub> emissions and costs. The results indicate that the assumption of storage costs is of great importance for the future total costs of an electricity system. Variations in other parameters led to different generation portfolios with similar system costs. Our results provide insights into future regional infrastructure needs, and underline the importance of regional coordination and governance for the energy transition in China.

**Keywords:** energy system modeling; power system optimization; sensitivity analysis; metropolitan region; energy transition; renewable energy

## 1. Introduction

Metropolitan regions are defined as cities and their surrounding areas with close socio-economic links and with a concentration of population, transport and economic activities that are largely dependent on imports from their hinterland [1]. The accelerated urbanization and industrialization in China is leading to major challenges due to rising energy demand and emissions, especially in the metropolitan regions on the east coast. The current serious urban air pollution and greenhouse gas emissions are mainly caused by local coal-dominated power and heating plants, as well as oil-fueled road transport. The electrification of heating and transport, combined with the decarbonization of the

power system, is therefore an important transition strategy for urban areas [2]. However, the current penetration of renewable energies in the power sector in China's metropolitan regions is quite low, with a share of less than 5% of total electricity generation (see Figure 1). The national average target for 2020 is 9%; the four regional targets of 5%, 7%, 10% and 13% are assigned to different provinces [3]. With the exception of the three provinces of Qinghai, Gansu and Ningxia, which exceeded in 2016 the targets set for 2020, most provinces still have large gaps in relation to the 2020 minimum targets, especially in the eastern provinces. The Chinese Renewable Portfolio Standard Policy (RPS) was released by the National Energy Administration (NEA) in February 2016, and aims to increase the penetration of renewable energy, especially in the centers of consumption, and to reduce wind and PV curtailment in the western provinces that are rich in renewable energy (RE), such as Inner Mongolia, Gansu and Ningxia [4]. However, due to relatively limited RE potential in the centers of consumption, the eastern coastal regions in particular will have to import large amounts of electricity from the surrounding renewable energy-rich regions [5,6]. To overcome the current curtailment of PV in the western provinces, the newly installed PV stations are now mainly located in the eastern provinces. The municipalities Beijing and Tianjin plan to further increase the share of imported electricity from the provinces of Hebei and Inner Mongolia to meet local climate targets and ensure the security of supply. By 2020, Beijing and Tianjin plan to import 10 TWh and 6 TWh annually, respectively, half of which will come from renewable sources [6]. By 2020, the installed renewable power capacity in Beijing-Tianjin-Hebei (BTH) region is expected to reach 45 GW [6].



**Figure 1.** Percentage of non-hydro renewable energy in electricity generated in 2016 compared to the regional 2020 targets [3], with an indication of possible regional power exchanges.

The aim of this case study is to investigate China's future power supply with temporal and spatial resolution. We focus on the interactions between two structurally very different regional systems regarding the integration of high shares of variable renewable energy (VRE). The study covers four megacities (Beijing, Tianjin, Shijiazhuang, Baoding) with a population of over 10 million [7], and nine other large cities. The case study considers Inner Mongolia as a resource-rich supply region, which is facing serious curtailment. In 2017, the curtailed wind power in Inner Mongolia reached 9.5 TWh [8].

The main research questions are how a predominantly renewable energy supply could be implemented, how much locally available renewable resources can be integrated into the power system and how much has to be imported from neighboring supply regions. In order to take into account the variable characteristics of PV and wind, the case study analyses the expansion and use of interprovincial power transmission capacities in temporal and spatial resolution. Furthermore, the modeling deals with the role of local storage expansion and the integration of electric vehicles (EVs) and power to gas into the future energy system. Since there are no long-term targets until 2050

in the form of regional CO<sub>2</sub> caps or specific shares of renewable energies, the following case study uses predefined regional CO<sub>2</sub> emission limits to analyze selected goal-oriented pathways for the power system. Our study provides insight into the investment decisions from the perspective of a social planner, which are necessary for the significant expansion of renewable energies, assuming minimal curtailment and system integration costs.

Several studies have already examined the transition path to decarbonizing China's power system beyond the National Determined Contributions for 2030 (for details see Table S1 in the supplementary material), but with different emphases:

Some have already analyzed the role of inter-regional transmission grid expansion due to load balancing between renewable energy-rich regions and the population-dense coastal east metropolitan regions [9,10]. Several addressed the required climate policies, such as the introduction of a CO<sub>2</sub> price, a CO<sub>2</sub> cap and RPS [9–12]. Among them, the linear optimization approach of minimizing the costs of producing and supplying electricity was widely used for the analysis of future power generation portfolios and corresponding investment in various options of power generation, storage and transmission [9,11,13,14]. Some studies have also discussed the robustness of constructed scenarios by analyzing future uncertainties, such as the CO<sub>2</sub> price, fuel prices, capital costs of energy technologies, RE penetration levels, solar and wind potentials, limitations of nuclear energy use and the projected electricity demand [9–11,13,15]. The in-depth analyses of [9] and [13] also focus on the issue at a national level with regard to policy options and transformation strategies.

However, to the best of our knowledge, no study has yet been conducted that incorporates the existing short-term climate policy defined by individual provinces or cities into its long-term transition modelling. Moreover, recent model-based studies have paid little attention to the sensitivities of the model results with respect to the calculated investments for China's future electricity system. Uncertainties that have not been adequately addressed so far exist in particular with regard to the costs of low-carbon technologies and other predefined system constraints [11,14–16] which can lead to significant variations in the generation system, both in terms of installed capacity and generated energy [17,18]. Compared to other applied scenario models, we have chosen a myopic approach to optimize the balance between electricity generation, demand, transmission and storage in an hourly resolution for each target year until 2050. This was done by calculating whole years with an hourly resolution instead of just analyzing typical daily load profiles without distinguishing between weekdays and weekend (e.g., [9]) or by considering selected time series (e.g., [13]) or only looking at the medium term until the year 2030 (see, e.g., [10,12,14,16]). Some studies ignored the dispatchable CSP technology (e.g., [13–15]), offshore wind and storage technologies (e.g., [16]) or considered only pumped hydro (e.g., [10]) as a storage option. This case study examines, for the first time, the possible future relationship between a solar- and wind-rich supply region and a metropolitan region with high demand using a target-oriented long-term scenario of the entire energy system, and by considering VRE as well as dispatchable CSP, biomass and geothermal technologies, grid expansion and other storage technologies beyond pumped hydro.


Our study is structured as follows. First, in Section 2, we present our methodology, input data and main assumptions. Based on that, Section 3 presents the optimization results for a defined reference scenario in terms of total installed capacity, required investments, annual energy and dispatch characteristics by region. In Section 4, we then analyze the influence of seven key parameters on installed capacity, full load hours of power generation and storage technologies, and total system costs. Finally, we discuss the results and come to our conclusions in Sections 5 and 6.

## 2. Methodology and Data

### 2.1. Methodology

The model framework REMix [17], developed at DLR, was parameterized for this case study according to the regional structures and boundary conditions. The model approach represents the

current state of research in the field of power system modeling, and has been applied in numerous research projects focusing on the German and European energy system [19–22]. It applies a cost minimization approach for capacity expansion planning and operation optimization with hourly resolution under certain constraints of CO<sub>2</sub> emissions and shares of renewable energy. A myopic modeling approach [23] was applied to calculate the transition path from 2020 to 2050 in 10 year steps (see Figure 2). In this approach, the result of one model run is used as the input for the next run. Essential input data are hourly resource time series, technology characterizations and scenarios of the electricity demand and power supply system. Historical weather data from the year 2001 are used to model future time series of power feed-in from renewable energy (RE) sources.



**Figure 2.** Renewable Energy Mix (REMIX) energy system model based on [17] and its application in this study.

REMIX consists of two model parts: REMIX-EnDat, for providing the temporal load and feed-in data for the model regions, and REMIX-OptiMo, for solving the optimization problem. REMIX-OptiMo is a deterministic linear optimization program developed using the general algebraic modeling system (GAMS), a high-level modeling language for mathematical programming and optimization. The model is based on a modular structure represented by techno-economic parameters of each considered technology, maximum installable capacities, specific investment and operation costs and efficiency. The applied modules represent power demand, variable and dispatchable renewable power generation, conventional power generation, power-to-power storage, power-to-hydrogen and direct current (DC) power transmission, and include a simplified representation of electric cars with assumptions about their load shifting potentials. Investments in new capacities consider technology cost, amortization time and interest rate, allowing the calculation of proportional capital costs for the chosen optimization periods [17]. The annual operating costs are calculated depending on the capacity of installed units and the annual power output. The latter may include variable production costs, fuel and CO<sub>2</sub> emission certificate costs [17], which are taken into account in the following sensitivity analysis (see Section 2.3.1). We do not apply costs for CO<sub>2</sub> emission certificates to the reference scenario, but consider a regional CO<sub>2</sub> cap (see Section 2.3.2). The model regions (in this case, two municipalities and two provinces) are represented by technology-specific power generation and storage, and are connected with transmission lines. The capacity expansion of power plants, grid and storage is optimized according to the available potentials and system constraints. The objective function is to minimize the total system costs for all analyzed regions, which consist of the proportional investment and fixed operating costs of all endogenously installed system components (added capacities) for one year of their amortization time and variable operating costs of the total capacities of all technologies. For VRE curtailment, we consider three operation modes: no curtailment, the option to fully curtail or curtailment up to a share of the theoretical amount of energy feed-in. The model contains a detailed representation of



Concentrating Solar power (CSP) plants to explore the abundant CSP potentials in Inner Mongolia for future power supply. They use direct solar radiation to generate steam for turbine operation. Equipped with thermal energy storage (TES) and backup firing systems, CSP plants can provide dispatchable or even continuous power generation. The total thermal capacity of the solar field is composed of the exogenously defined existing capacity and the endogenously calculated added capacity, whereby the total capacity is limited to the potential determined by EnDAT. The hourly changes in the TES energy level are described by the storage balance, which is represented by charging, discharging and self-discharging [17]. In the following analysis, natural gas is used as back-up fuel in CSP plants. Power generation in the biomass and geothermal module is restricted by the available resources. For fossil fuel power plants, fuel consumption is calculated via the net efficiency of power generation. Additionally, fuel costs and CO<sub>2</sub> emissions and costs are calculated. Controlled charging of electric vehicles (EVs) was only considered for passenger cars. The additional power demand for electric mobility was derived from a comprehensive normative scenario for China from [24]. In this study, a so-called Renewable & Import Scenario (RIS) was developed that covers high market penetration of renewable energies and achieves a carbon emission reduction in line with the national 2 °C target (see Table S2 in the supplementary material). The regional power system is optimized regarding supply costs within predefined system constraints such as maximum CO<sub>2</sub> emissions and a minimum share of renewable energy (see in detail Section 2.3.2).


## 2.2. Input Data

### 2.2.1. Power and Hydrogen Demand

The hourly power demand curve is based on data from the China Southern Power Grid Company, and was modified according to the annual demand of each modeling node based on the Renewable & Import Scenario (RIS) analysis for the Beijing-Tianjin-Hebei (BTH) region. Future power demand is determined by the high electrification rate in the heat and transport sectors, in line with the RIS scenario with consideration of improvements in efficiency [24]. The additional electricity and hydrogen demands resulting from the inclusion of battery electric and hydrogen vehicles are also derived from assumed market shares for passenger cars (PC) and light duty vehicles (LDV) under RIS [24] (see Table S2 in the supplementary material). It is further assumed that half of the energy consumed by hybrid vehicles comes from electricity. The share of electricity used for PC and LDV would increase from 4% in 2015 to 55% in 2050. The absolute consumption values derived from RIS and taken into account in the modeling are 229 TWh electricity for electric vehicles and 74 TWh hydrogen for fuel cell vehicles in 2050.

### 2.2.2. Renewable Energy Potentials for Power Generation

The analysis of the regional potential of renewable energy resources in China is the basis for assessing how the decarbonization of the urban power sectors can be supported by electricity imports. For this purpose, a GIS-based calculation of total and hourly generation potentials was carried out drawing upon on global weather data [25], spatial exclusion masks and assumptions about the average characteristics of future technologies [26,27] (for details, see Chapter 1 in the Supplementary Material). The analysis quantified the limited renewable energy resources available in the metropolitan region in contrast to the enormous potential of solar energy and onshore wind in the neighboring Inner Mongolia region, which, compared to the demand for electricity, illustrates the possibility of exporting electricity (see Figure 3).



**Figure 3.** Renewable energy resources assessment compared to projected power demand in 2050 in supply region of Inner Mongolia and the metropolitan region of BTH (includes the demand from electric vehicles under RIS scenario).

### 2.2.3. Existing Installed Capacities and Short-Term Targets

We take into account the currently installed power generation capacities of photovoltaic (PV), wind (onshore and offshore), biomass, geothermal, concentrating solar power (CSP) as a baseline. Additionally, we consider policy targets, e.g., for grid connection by 2020 or 2030 if available at provincial (for Hebei and Inner Mongolia) and municipal level (for Beijing and Tianjin) [28–30] (see Table S3 in the supplementary material). Hebei and Inner Mongolia aim to increase installed onshore wind capacity to 18 GW and 45 GW, respectively, by 2020. Hebei province plans to install 1 GW of CSP by 2020 [31] while Inner Mongolia's targets are 3 GW by 2020, 6 GW from 2020 to 2025, and 7 GW from 2025 to 2030 [32]. Existing installed capacities and short-term targets are used as exogenously defined (minimum) input capacities, which are reduced according to the assumed lifetime of each technology and supplemented by the endogenously calculated added capacities. The World Electric Power Plants Database (2015) [33] provides the exogenously assumed capacities for conventional power plants with combined cycle gas turbine (CCGT), gas turbine (GT), coal and lignite in the base year 2015 (see Table S4 in the supplementary material). Currently there is no nuclear power plant in the study region and it is assumed, in line with the RIS scenario, that there are no further plans for nuclear power plants in inland China. Without investments in new coal-fired power plants, the remaining capacity in Hebei and Inner Mongolia would be 10 GW and 8 GW in 2050, respectively, as a result of the decommissioning in accordance with the expected technical lifetime.

## 2.3. Further Assumptions

### 2.3.1. Technical-Economic Parameters

For the prospective analysis of electricity generation from renewable energy and transmission and storage technologies cost reductions and efficiency improvements are assumed according to Tables 1 and 2. The solar multiple (SM) is defined as the ratio of the thermal output of the solar field to the thermal input of the steam turbine. In the system modeling, SM is freely optimized and the heat storage is added to the system according to this design parameter. The heat balance is determined by the thermal output from the solar field and the backup unit as well as by the charging and discharging of the heat storage in interaction with the power generation and curtailment. For the provision of firm capacity, all CSP plants use natural gas-fired backup systems that allow full-load power block operation.

**Table 1.** Assumed economic and technological parameters for power generation based on [34,35].

Technology	Investment Costs				Fixed O&M Costs	Variable O&M Costs	Efficiency	Availability	Amortization Time
	(€/kW)				% of Investment Costs/yr	€/MWh	%	%	yrs
	2020	2030	2040	2050	2020 ~ 2050				
Onshore wind	861	832	818	789	4	0	n/a	92	25
Offshore wind	2400	2200	2000	1800	5.5	0		92	25
PV	689	603	502	430	1	0		95	25
CSP_power block	980	980	980	980					40
CSP_solar field	399	320	256	192	2.5	2.2	37	95	25
CSP_thermal storage	38	29	24	19					25
Biomass	2400	2200	2100	2000	4	2	30	90	25
Geothermal	10000	9000	8000	7600	4.5	0	9 ~ 11	95	20
Gas turbine (GT)	437	437	437	437	4	0	43.6 ~ 46.5	95	25
CCGT	850	850	850	850	4	0	60 ~ 63	96	25
Coal	1500	1500	1500	1500	4	0	46.8 ~ 49.1	90	40
Lignite	1640	1640	1640	1640	4	0	50 ~ 51	91	40

**Table 2.** Assumed economic and technological parameters for electric energy storage [35].

	Investment Costs (2020 ~ 2050: €/kWh)		Amortization Time (2020 ~ 2050: yrs)		
Technology	Storage	Converter	Storage	Converter	
Pumped hydro	10	530 ~ 450	60	20	
Lithium-ion battery	300 ~ 150	100 ~ 50	21 ~ 25	21 ~ 25	
Hydrogen storage	1	1500 ~ 1200	30	15	
CAES_AD	41 ~ 47	1020 ~ 570	40	20	
	Fixed O&M Costs	Availability	Efficiency (%)		
	% of Investment Costs/yr	%	Charge	Discharge	Self-Discharge Rate of Storage per Hour
Technology	2020 ~ 2050				
Pumped hydro	1	98	89 ~ 91	89 ~ 91	0.0005
Lithium-ion battery	0.9 ~ 0.5	98	93 ~ 97	93 ~ 97	0.0011
Hydrogen storage	2	95	71 ~ 75	60 ~ 62	0
CAES_AD	1 ~ 2	95	81 ~ 84	86 ~ 89	0.08

Four different electricity storage technologies are considered in the modeling. The energy storage unit and the converter unit are modeled separately in REMix, taking into account the installation costs as well as fixed and variable operating costs. The operating costs depend directly on the stored electricity.

The assumed economic and technological parameters for electric cars and electrolyzers for onsite hydrogen generation at filling stations are shown in Tables 3 and 4. The installed electrolyzer capacities and full load hours for hydrogen production are freely optimized. Three different CO<sub>2</sub> certificate price developments are considered in the following sensitivity analysis (see Table 5).

**Table 3.** Assumed economic and technological parameters for electric cars [35].

Year	Availability of Delayed Loading %	Ratio of Charging Capacity and Maximum Charging Load /	Variable O&M Costs (Load Shifting) € ct/kWh
2020	15	2	1
2030	30	2	1
2040	45	2	1
2050	60	2	1


**Table 4.** Assumed economic and technological parameters for local electrolyzers used for hydrogen cars [35].

Year	Efficiency %	Investment Costs €/kW <sub>el</sub>	Amortization Time yrs	Fixed O&M Costs % of Investment Costs/yr	Variable O&M Costs € ct/kWh <sub>el</sub>
2020	70	527	30	1.5	0.1
2030	70	439	30	1.5	0.1
2040	70	366	30	1.5	0.1
2050	70	305	30	1.5	0.1

**Table 5.** CO<sub>2</sub> certificate price development paths according to [36,37] assumed for sensitivity cases (unit: €/tCO<sub>2</sub>).

Year	Certificate Price Low	Certificate Price Medium	Certificate Price High
2020	10	20	30
2030	20	37	73
2040	30	53	117
2050	40	70	160

The assumed price paths for fossil fuels are shown in Figure 4 based on [35]. The high development paths are assumed for the scenario analysis, the low development paths are used for the sensitivity analysis in Section 4.

**Figure 4.** Assumed development paths for fossil fuel prices.

Transmission grid capacity expansions are limited to point-to-point HVDC technology between neighboring modeling nodes. There are currently ten extra-high voltage direct current (EHV-DC), three ultra-high voltage alternating current (UHV-AC) and six UHV-DC transmission lines existing in China and three UHV-AC transmission lines are planned to be commissioned by 2020 [5]. They are being considered as options for connecting RE supply regions with consumption centers in the eastern coastal region.

For simplification, all the historic and scenario transmission capacities are aggregated by model nodes and represented by HVDC transmission technology. Between the region of Beijing-Tianjin-Hebei and Inner Mongolia 6 HVDC transmission lines are modeled with a rated power of 1000 MW each according to the current national grid plan for 2020 [5]. The investment costs for overhead lines are assumed to be 544 k€/km [35] and additional costs for the installation of each converter station are assumed with a reduction trend (see Table 6). The amortization time of transmission lines and converters is assumed to be 40 and 20 years, respectively. The annual fixed operating costs are assumed to be 1% of the investment. The power flow over each connection is limited by the predefined capacity of the available lines.

**Table 6.** Assumed costs of converter stations for HVDC transmission lines (unit: Mio. €) [35].

2020	2030	2040	2050
108	102	96	90

The distances between the modeled regions, defined as the distance between the capital of each province and the two municipalities, are listed in Table 7. A length factor of 1.2 is assumed for this analysis between the geographical distance and the length of the overhead transmission lines.



**Table 7.** Assumed distances between the four model regions (unit: km).

Connection	Assumed Transmission Line Length
Beijing—Tianjin	115
Beijing—Hebei	265
Beijing—Inner Mongolia	406
Tianjin—Hebei	262
Tianjin—Inner Mongolia	506
Hebei—Inner Mongolia	396

Furthermore, a fixed capital interest rate of 6% is assumed for all investments in new power generation, storage and grid technology.

### 2.3.2. System Constraints

Based on the scenario analysis of the carbon emission path for the Chinese power sector by [9] this study assumes a national CO<sub>2</sub> cap of 4.5 Bt in 2020, with reductions to 3 Bt by 2030, 2 Bt by 2040 and 1 Bt by 2050, respectively. This mitigation path is in line with the IPCC targets to achieve a reduction in carbon intensity by 2020, to reach an emission peak by 2030 and to achieve a reduction of CO<sub>2</sub> emissions for China of at least 80% by 2050 compared to 1990 levels. The regional CO<sub>2</sub> caps are derived from the current CO<sub>2</sub> emissions in the power sector according to the Multi-resolution Emission Inventory for China (MEIC) database [38]. It is assumed that by 2050, at least 60% of electricity would be theoretically generated from renewable energies of solar and wind in all regions considered. The shares are allocated to each province/municipality based on the available 2020 targets (see Table 8). Furthermore, grid expansion between supply region and consumption centers is limited to a maximum of 50 transmission lines per transmission corridor with a total rated power of 50 GW for reasons of acceptance and feasibility.

**Table 8.** Assumed theoretical solar and wind shares in the power sector by model region and regional CO<sub>2</sub> emission limits.

Minimum Theoretical Share of Solar and Wind in the Power Sector (%)	Beijing	Tianjin	Hebei	Inner Mongolia	Regional CO <sub>2</sub> Emission Limit in the Power Sector (Mt)
2020 (targets)	10	10	10	13	700
2030	18	18	18	24	470
2040	38	38	38	43	300
2050	58	58	58	64	150

## 3. Optimization Results

This section provides the quantitative results of the reference scenario analysis in terms of installed capacity, investment and fuel costs, annual electricity production and resulting CO<sub>2</sub> emissions, as well as hourly dispatch for the modeled regions. Furthermore, the required grid expansion between the regions is calculated under the objective function of minimized system costs.


### 3.1. Summary of Key Results

The optimization results for the reference scenario show that under the given assumptions and system constraints, the share of renewable energy in installed power generation capacity and annual electricity production would significantly increase under the RIS in both the BTH metropolitan region and the Inner Mongolia supply region (Table 9). However, in Beijing and Tianjin, renewable electricity generation only reaches around 60% by 2050, while the share increases to 74% in Hebei province and 98% in Inner Mongolia.

**Table 9.** Solar and wind share of energy in terms of installed capacity and annual generation (with the consideration of curtailment) by model region.

<b>Installed Capacity</b>	<b>2020</b>	<b>2030</b>	<b>2040</b>	<b>2050</b>
Beijing	16%	25%	26%	34%
Tianjin	21%	43%	52%	56%
Hebei	55%	78%	85%	86%
Inner Mongolia	64%	76%	84%	98%
<b>Annual Electricity Generation</b>	<b>2020</b>	<b>2030</b>	<b>2040</b>	<b>2050</b>
Beijing	13%	25%	38%	58%
Tianjin	10%	27%	43%	64%
Hebei	31%	56%	71%	74%
Inner Mongolia	61%	80%	91%	98%

CO<sub>2</sub> emissions from power generation in the two municipalities would only decrease after 2030 under the current short-term policy till 2020 and the set system constraints (Table 6). In contrast, emissions in Hebei and Inner Mongolia could be reduced immediately under the same scenario, indicating that renewable technologies are already the most cost effective technologies in these regions. These results reveal that the current short-term policy till 2020 is not yet sufficient to stop the growth of CO<sub>2</sub> emissions in municipalities in the medium term. However, with the further expansion of renewable energies for power generation and the implementation of regional CO<sub>2</sub> emission caps, emissions in the metropolitan region could be reduced to 53% by 2050 compared to the 2010 level (see Figure 5).

**Figure 5.** CO<sub>2</sub> emissions from power generation between 2010 and 2050 for BTH and Inner Mongolia.

The optimization results show that the mean value of marginal electricity generation costs would increase moderately till 2040 in all modeled municipalities and provinces (see Figure 6). With better solar and wind resources, Inner Mongolia has lower marginal costs compared with the metropolitan region that are below 56 €/MWh. The average marginal electricity costs in Inner Mongolia are used to calculate the imported electricity costs for the metropolitan region, which have to be added to the cost for its transformation of the energy system.




Figure 6. Mean marginal electricity costs over the optimization period by model region.

### 3.2. Total Installed Capacity

Figure 7 shows the total installed capacities for power generation, electricity storage and grid transmission as a result of exogenously assumed existing installations and additionally required capacities as endogenous result of the system optimization. The total installed fossil-fired power plant capacity in the BTH region decreases after 2040 but only slightly and in line with the requirement of the total CO<sub>2</sub> emission cap. A switch from coal to gas does not take place in power generation in BTH due to the neglect of CO<sub>2</sub> emission costs and the cost advantages of extensive emission reduction in the Inner Mongolia supply region (see Figure 6). The share of PV in total installed capacity increases from 16% in 2020 to 73% by 2050 in BTH. Limited by the regionally available onshore wind potentials (36 GW and 31 GW if all sites below 4 m/s and 5 m/s wind speed, respectively, are considered) and noncompetitive costs for offshore wind energy, wind installations stagnate and the share of wind in total capacity decreases from 26% in 2020 to only 7% by 2050 in the BTH region. The maximum regional potential of biomass is exploited by 2050, while only the planned capacities for geothermal energy and CSP are installed due to the higher costs compared to other technologies. The maximum potential for pumped hydro is fully exploited already by 2020. This leads to a continuous increase in installed capacity in the BTH region mainly for lithium-ion battery, but also for local electrolyzers and adiabatic compressed air energy storage (CAES\_AD) from 16 GW, 3 GW and 0 GW in 2030 to 55 GW, 16 GW and 11 GW by 2050, respectively, to balance the increasing variable generation of PV.

In contrast to the metropolitan region, both PV and onshore wind energy would dominate the power supply system in Inner Mongolia (with a growth from 60% in 2020 to 96% by 2050) in terms of installed capacity (see Figure 8). Since PV has lower electricity generation costs compared with onshore wind, large amounts of PV are installed in the supply region in the period 2040–2050 (315 GW). Similar to BTH, only the planned installed capacity for geothermal and CSP are installed due to the higher costs compared to other technologies. The maximum regional potential of biomass is also exploited in Inner Mongolia by 2050. The growth in installed capacity for storage technologies shows a similar trend to that in the metropolitan region, especially for the expansion of lithium-ion battery in the last decade of the scenario as a result of the large-scale installation of PV. The installed capacity for fossil-fired generation decreases by 80% from 69 GW in 2020 to 14 GW by 2050. The installed capacities for RE and backup power generation, storage and transmission can ensure that the growing power demand both in the metropolitan regions and in the supply region is covered in every hour of the modeled years.




Figure 7. Total installed capacity by technology in the BTH metropolitan region.





Figure 8. Total installed capacity by technology in the supply region of Inner Mongolia.

### 3.3. Required Investments

In the metropolitan region, investment in renewable power plants rises sharply in this scenario from 67 billion € in the period 2015–2020 to 214 billion € in the period 2040–2050 (see Figure 9). In contrast, investment in fossil-fueled power plants peaks in 2020–2030 and declines to 95 billion € over the last decade. Total investment in renewable power plant capacity exceeds that of fossil fuels after 2030. Compared to the relatively high investments in power generation capacity, storage expansion requires only between 9 and 72 billion € for each decade from 2020 to 2050. Investments in storage facilities are dominated by lithium-ion batteries for short-term load balancing due to a PV dominated power supply system, which have less limited potential than pumped storage facilities. There is also a limited investment in local electrolyzers and after 2030 additional investment in CAES\_AD. Investments in biomass, onshore wind and CSP remain rather stable for each decade at around 20 billion €, 30 billion € and 3 billion €, respectively. Due to the fast expansion of PV in the BTH region, investments also significantly increase from 88 billion € in the period 2020–2030 to 162 billion € in the last decade. In comparison, investment in wind power remains at a lower, and in the long run even slightly declining, level, with only small investments in offshore wind in line with planned capacities by 2020. The reason for this is on the one hand the limited regional onshore wind potential and the assumed relatively higher offshore wind costs at relatively low full load hours (FLH) in the region. On the other hand PV generation in the region in combination with imported electricity from onshore wind energy is advantageous from a system perspective.




**Figure 9.** Investments in total installed capacities by technology in the BTH metropolitan region.

In the Inner Mongolia supply region with an onshore wind and solar dominated power supply system, large investments in wind power plants would be required in each decade (from 151 billion € in the period 2020–2030 to 209 billion € in the last decade) (see Figure 10). Investment in PV capacity only increases significantly in the last decade (to 136 billion € per decade). Investment in fossil-fueled power plants decline from 105 billion € in 2020–2030 to only 21 billion € in the last decade. With CSP installed capacity declining after 2040, more investment is needed for lithium-ion batteries and CAES\_AD to balance variable PV and onshore wind power generation. The storage demand arises mainly with




regard to short-term load balancing by lithium-ion batteries with a lower demand for local electrolyzer than in the BTH region. Investments in biomass power plants per decade remain relatively stable at around 20 billion €.



**Figure 10.** Investments in total installed capacities by technology in the supply region of Inner Mongolia.

During the transition process in the energy system, according to the scenario calculations, additional investments are also required for grid expansion, with an increase from 26 billion € in the period 2020–2030 to 38 billion € in the last decade (see Figure 11). Such investments are led by the grid expansion of 16 GW from Inner Mongolia to Beijing and Tianjin in 2020 to 68 GW from Inner Mongolia to the BTH region and 2 GW from Tianjin and Hebei to Beijing.



**Figure 11.** Total installed transmission capacity (incl. grid expansion) between the four model regions with corresponding investments by decades from 2015 to 2050.

### 3.4. Annual Power Supply

Figure 12 shows that from 2020 to 2050 electricity imports for the metropolitan region increase due to the additional power demand from heating and transport and the massive installation of RE generation capacity in the supply region. The share of imported electricity in total power demand rises to around 30% by 2050. According to the modeling results, a cost-minimized electricity system would require substantial electricity imports already in the first scenario year 2020. By 2050, PV dominates the power supply system in the BTH region (28%) while onshore wind dominates in the supply region (69%). Accordingly, electricity generation from coal power plants would decline in both regions after 2020. Given the limited potential for pumped hydro storage, other storage technologies such as lithium-ion batteries, hydrogen and CAES\_AD play an increasingly important role in a VRE dominated power supply system equally in metropolitan and supply regions with full load hours increasing over time. Local on-site electrolyzers can generate hydrogen as a renewable fuel and help to integrate VRE into the power system, especially in the BTH region. With increasing shares of renewable power generation, there will be a change in the backup power supply from CCGT to GT in the long-term. For reasons of supply costs and by exploiting the given CO<sub>2</sub> caps, a high proportion of coal-fired power plants remains. This effect is reinforced by the fact that no CO<sub>2</sub> costs are assumed in the reference scenario. In parallel to these developments, the curtailed energy in Inner Mongolia rises dramatically from 1% in 2020 to 11% by 2050, mainly from onshore wind (60%) and PV (33%).





Figure 12. Annual power supply for the metropolitan and the supply region from 2020 to 2050.

### 3.5. Hourly Dispatch Characteristics

The hourly balance between power generation, storage, transmission and demand shows typical seasonal variations in the study regions. In this section, the hourly dispatch in the years 2030 and

2050, which have significantly different characteristics, is discussed on the basis of selected results (for details see the Supplementary Material).

In 2030, Beijing's power supply system would be dominated by imported electricity and storage by pumped hydro. Lithium-ion batteries, hydrogen and EVs still play a minor role in balancing PV and onshore wind, and there is no curtailment of variable generation yet. From our results we identify three characteristic seasons: From February to May, coal and biomass need to be operated flexibly, supplementing imported electricity and power generation from PV and onshore wind to meet the hourly power demand pattern. From June to October, coal and biomass power plants are operated as base loads with GT and CCGT as flexible generators. From November to January, GT and CCGT are not operated; at the same time, power plants using coal and biomass are operated as base load power generators (see Figure 13).



**Figure 13.** Typical hourly generation by technology, export and charge (–), import & discharge (+) to meet Beijing's power demand of April, August and November 2030.

Tianjin in 2030 would have a lower share of imported electricity than Beijing. Overall the dispatch has quite similar characteristics than the one in Beijing, however, with considerably higher generation from coal and lower electricity import shares (see Supplementary Material).

In contrast to the two municipalities, onshore wind also plays a major role in Hebei province in 2030 resulting in less import. CSP would operate intermittently in this scenario, especially when PV is not available. Due to the limited potential of pumped hydro storage, more lithium-ion batteries are needed to balance PV in such a system. Coal and biomass power plants are operated flexibly from January to May with increasing curtailment of PV systems over time. From June to August, coal and biomass would act again as base load power plants, GT and CCGT would be operated flexibly, and there would be no curtailment of PV and wind. The higher PV share can be balanced out by the lithium-ion battery and even leads to exports at peak times. After September, the share of power generation from onshore wind increases, while exports of electricity from PV and flexibly operated coal and biomass power plants decline.


As a supply region, Inner Mongolia in 2030 has a power system dominated by onshore wind with a high share of exported electricity. CSP would operate intermittently when PV is not available to meet peak demand and balance base loads. The local pumped hydro potentials could mostly cover the demand for balancing variable wind and solar energies. Due to the still low power consumption from EVs compared to the total power generation demand, EVs would only play a minor role in load balancing. From January to May, coal and biomass power plants would be operated flexibly, with wind and solar energy being severely curtailed during peak periods. From June to October, coal and biomass would operate in baseload with less curtailment, whereas in November and December they would run more flexible, again with increasing curtailment.

In Beijing in 2050, the share of electricity imports further increases with higher demand for hydrogen and electricity for EVs. Still, during several periods of lower demand, PV and onshore wind will be curtailed. From February to May, local PV tends to be unused because of relatively cheap imported electricity. From June to January, coal, biomass and GT are operated as flexible generators and local PV is used most of the time, resulting in less curtailment.

Compared to 2030, the share of imported electricity increases also in Tianjin, while at the same time the curtailment of PV systems becomes more severe. Different from Beijing, CAES\_AD would also act as a short-term storage together with EVs, pumped hydro, lithium-ion batteries and flexible hydrogen systems. During several periods, the power supply is completely based on renewable energies, but with high curtailment of PV.

In Hebei, a large share of lithium-ion battery is installed in 2050 to balance PV power generation. From February to May, the power supply system is dominated by PV and onshore wind with an increasing curtailment rate. In June and July, coal, biomass and GT would operate flexibly with a still PV dominated power supply system, but with less curtailment and increasing export. From August to January, coal and biomass would act as base load generators with flexibly operated GT, an increasing share of onshore wind, and less curtailment.

In the scenario, Inner Mongolia still has a power system dominated by onshore wind in 2050, but with a higher share of PV compared to 2030 (see Figure 14). Besides the fully exploited storage potential of the pumped hydro, lithium-ion batteries would dominate the storage system together with CAES\_AD and hydrogen. In contrast to the metropolitan region, EVs would only play a minor role even in 2050, since in relation to total electricity generation, significantly fewer EVs would be available. From January to May, the power system is completely based on renewable energies, with flexibly operated biomass power plants and increasing curtailments of onshore wind and PV over time. In June and July, the remaining coal-fired power plants need to be flexibly operated and PV dominates the power system instead of onshore wind. From August to December, coal and biomass power plants act as base load power plants, but only play a minor role, with less curtailment and an increasing power generation from onshore wind energy.



**Figure 14.** Typical hourly generation by technology, export and charge (-), import & discharge (+) to meet power demand in Inner Mongolia of April, August and November 2050.



#### 4. Sensitivity Analysis


The modeling results of the reference scenario shown above are based on a cost optimization approach and are therefore dependent on uncertain cost assumptions for the future [39,40]. Other parameters also influence the results, such as used historic time series for the power generation from renewable energies and exogenously defined system constraints. In this section, the influence of costs assumptions and selected constraints on main output parameters for the power generation structure, all storage technologies and grid expansion is discussed. In addition to the technology costs, the sensitivity analysis was also conducted for CO<sub>2</sub> certificate price assumptions, the restriction of grid expansion, the limitation of curtailment of power generation from VRE and CSP, the fossil fuel price paths and the FLH of available offshore wind. The parameter variations are defined in Table 10. The sensitivity analysis considers the influence of assumptions on installed capacity portfolios, annual electricity generation, CO<sub>2</sub> emissions and system costs.

**Table 10.** Scenario assumptions for the sensitivity analysis.


Scenarios	Assumptions
VRE_Inv_low	Decrease of investment costs for VRE technologies by 50%
VRE_Inv_high	Increase of investment costs for VRE technologies by 50%
Stor_Inv_low	Decrease of investment costs for converter and storage units by 50%
Stor_Inv_high	Increase of investment costs for converter and storage units by 50%
Grid_Inv_low	Decrease of investment costs for transmission grid expansion by 50%
Grid_Inv_high	Increase of investment costs for transmission grid expansion by 50%
CO <sub>2</sub> _price_low	Assumption of a low CO <sub>2</sub> certificate price path
CO <sub>2</sub> _price_medium	Assumption of a medium CO <sub>2</sub> certificate price path
CO <sub>2</sub> _price_high	Assumption of a high CO <sub>2</sub> certificate price path
Cur_restriction_20%	Restricted curtailment ratio for VRE and CSP by region and year (below 20% in 2050)
Cur_restriction_10%	Restricted curtailment ratio for VRE and CSP by region and year (below 10% in 2050)
Cur_restriction_5%	Restricted curtailment ratio for VRE and CSP by region and year (below 5% in 2050)
Grid_restriction	No further transmission grid expansion from Inner Mongolia to BTH region is allowed (except current or planned transmission capacities)
FFP_low	Assumption of a low development pathway for fossil fuel prices (FFP)
Offshore_FLH_high	Assumption of higher FLH for offshore wind times series from surrounding coastal Liaoning and Shandong provinces (see Figure S1 in the supplementary material)

##### 4.1. Influence on Installed Capacities and Annual Electricity Generation


Figures 15–18 show for both regions the results of the sensitivity cases for the calculated installed capacity and annual electricity generation by technology in 2050 compared to the reference scenario. Of all the cases analyzed, a restricted grid expansion from Inner Mongolia to the BTH region has the highest influence on both the installed capacity and the electricity generation structure in the BTH region (see Figures 15 and 16). Under this assumption, the regional offshore wind resources of 64 GW would be fully exploited. Furthermore, such a scenario results in a shift from gas turbines to CCGT and to an additional grid expansion of 10 GW within the BTH region. Compared to the reference case, 26 GW lithium-ion batteries, 37 GW CCGT and 1 GW onshore wind would be additionally installed to compensate for the reduced electricity imports. In contrast to the metropolitan region, the influence of parameter variations in Inner Mongolia is particularly evident in changes in the shares of wind, solar and storage technologies due to the high share of renewable energy supply (see Figures 17 and 18). This is also the reason why variations in investment costs for VRE and storage systems have the largest influence of all scenario variants in Inner Mongolia.




**Figure 15.** Sensitivity analysis on total installed capacities of 2050 in BTH shown as deviations from the reference scenario.



**Figure 16.** Sensitivity analysis on annual electricity generation of 2050 in BTH shown as deviations from the reference scenario.



**Figure 17.** Sensitivity analysis on total installed capacities in 2050 in Inner Mongolia shown as deviations from the reference scenario.



**Figure 18.** Sensitivity analysis on annual electricity generation in 2050 in Inner Mongolia shown as deviations from the reference scenario.

The effects of assumed CO<sub>2</sub> certificate prices on the power system also differ for the two regions. For the BTH region, CO<sub>2</sub> certificate prices would contribute to the further reduction of coal and gas turbine power plants. The highest CO<sub>2</sub> certificate prices would result in a further installation of lithium-ion batteries and hydrogen storage as well as to more imported electricity from Inner Mongolia. In Inner Mongolia, higher CO<sub>2</sub> certificate prices would promote the further expansion of photovoltaic, onshore wind, storage technologies of lithium-ion batteries, hydrogen storage and CAES\_AD, and the grid. Higher investment costs of VRE technologies would result in a shift from PV, onshore wind and storage technologies to dispatchable CSP systems with an additional expansion of the grid between Inner Mongolia and the BTH region.


Quite different effects on the two regions also derive from assumed reduced investment costs for storage technologies, decreased VRE investment costs, and a low development path for fossil fuel prices. Under these assumptions, the installed capacity of coal power plants will be significantly reduced by 33 to 38 GW in BTH by 2050. However, this would have to be compensated for by additional installations of various storage technologies (including hydrogen)—each less than 20 GW—and an expansion of up to 6 GW grid transmission capacity. In contrast, these three cases each show significant and different effects on the RE power generation structure in combination with storage demand in Inner Mongolia, with a slight increase in gas consumption in the case of lower fossil fuel prices.

Lower effects are visible for both regions if the costs for grid expansion are changed or the curtailment rate is restricted to 20%. If only a maximum of 10% to 5% curtailment is allowed, some relevant effects become visible. In the case of BTH, a small switch from gas to coal in combination with higher storage demand (above all batteries) can be observed, with some effects on electricity import and PV. In Inner Mongolia, a 5% curtailment restriction leads to significantly lower PV and wind installation and generation in combination with less grid and short-term storage expansion, but with some shift to CSP and hydrogen storage. Furthermore, assuming higher FLH of offshore wind power plants would not increase the use of regional offshore wind resources.


In addition, the results of the sensitivity analysis for the corresponding full load hours of electricity generation and storage technologies are provided in Chapter 2 in the Supplementary Material. However, the results on the power supply structure only represent the technical perspective. Regarding the environmental and economic effects, we therefore present in the following sections the effects of structural changes in power systems on CO<sub>2</sub> emissions and system costs.

#### 4.2. Influence on CO<sub>2</sub> Emissions

The differing CO<sub>2</sub> emissions of the analyzed generation structures are shown in Figures 19 and 20. The analysis clearly shows that setting prices for CO<sub>2</sub> certificates is an effective measure to further reduce CO<sub>2</sub> emissions by reducing the FLH of fossil fuel power plants. In addition, lower investment costs for VRE technologies, storage systems and grid expansion would further promote the market penetration of renewable energies with storage and power exchange, which would significantly reduce emissions in the medium to long term. On the other hand, higher investment costs and a restricted grid expansion would delay regional CO<sub>2</sub> emission reduction, especially in the medium term. A special case is the assumption of low prices for fossil fuels. This leads to significantly higher emissions in 2030 due to the economic advantages of coal firing, but in the long term, assuming the CO<sub>2</sub> cap, it would result in a significant switch from coal to gas by 2050 and correspondingly lower specific emissions from power generation.



**Figure 19.** Sensitivity analysis on CO<sub>2</sub> emissions in BTH of 2030 (whole column) and 2050 shown as deviations from the reference scenario.




**Figure 20.** Sensitivity analysis on CO<sub>2</sub> emissions in Inner Mongolia of 2030 (whole column) and 2050 shown as deviations from the reference scenario.

#### 4.3. Influence on Total System Costs

The influences of the parameter variations on the total system costs are shown from 2030 to 2050 in Figure 21. The total system costs are calculated from the annuities of investments of all endogenously installed capacities, the fuel costs, the fixed and variable operational and maintenance costs and the

operating costs for load shifting by electric vehicles. The influence of storage costs clearly dominates the variation of system costs over the entire time horizon and leads to positive and negative deviations from the reference scenario of over 150 billion € in BTH and 100 billion € in Inner Mongolia. The reason behind is that storage costs significantly influence both the installation of fossil fuel power plants in the BTH region and of RE capacities in Inner Mongolia. This result is particularly relevant when one considers that many storage technologies are still at the beginning of the learning curve [41,42]. The uncertainties of cost assumptions are therefore often high, and large cost reductions are expected with further development [43]. Compared to that, all other parameter variations result in relatively small deviations from the reference case, up to a maximum of less than 25 billion €. Although the variation in investment costs for VRE in Inner Mongolia, the grid restriction to the BTH region, and the setting of CO<sub>2</sub> certificate prices in both regions lead to the highest variations in installed capacities, their impact on the system costs is rather small. Similar conclusions can be found in other sensitivity studies for power systems dominated by renewable energies [17,18,44].



**Figure 21.** Sensitivity analysis on system costs from 2030 to 2050 in both regions shown as deviations from the reference scenario.

## 5. Discussion

Our analysis considers a variety of options to supply a metropolitan region of China with renewable power. Biomass, PV and wind appear to be more cost competitive than dispatchable power generation from CSP and geothermal energy, of which only the currently planned capacities are operated at the modelled system cost minimum. Since the regional potential of pumped hydro power is already exploited before 2030, there is a high correlation between the installation of PV and lithium-ion batteries, which is observed from 2030 to 2050 in BTH and in 2050 in Inner Mongolia. Offshore wind energy within the BTH region is only cost competitive if further imports are restricted. Thus, the two municipalities of Beijing and Tianjin will largely depend on imported electricity, which also supports the findings of [14]. In Hebei province, the power system in 2050 is dominated by PV supplemented with onshore wind and some residual coal in the winter season. Inner Mongolia's power system is dominated by onshore wind energy, especially in the winter season. Dispatchable CSP will be a pillar both locally and for export, an aspect often neglected in previous studies (see Table S1 in the supplementary material). Compared to the metropolitan region, the role of electric vehicles in its



renewable energy-dominated power system is rather small. The hydrogen systems, compressed air storages and natural gas turbines are operated flexibly to compensate for deficits from import during the night. In Inner Mongolia, storage and grid technologies are of complementary importance to balance peak PV generation during the day and low onshore wind generation at night.

Considering the bandwidth of our sensitivity analysis, we see significant impacts of higher or lower investment costs for VRE and storage on installed capacity in both regions as also shown in [11,13,15]. The introduction of a CO<sub>2</sub> pricing system is an effective measure to further reduce regional CO<sub>2</sub> emissions, but due to different strategies in the two regions. In the metropolitan region we see a strong shift from coal to gas and only little additional renewable generation. In Inner Mongolia there is a major shift in renewable installations. Curtailment restrictions seem to be of minor importance. This is also reflected in the variation of the FLH of all technologies in the sensitivity analysis. We see major differences above all in the dispatchable technologies in both regions.

From a system perspective, our sensitivity analysis reveals how the development of storage costs overshadows all other effects of cost variations and constraints. This is particularly interesting because storage systems include technologies with so far quite uncertain cost learning curves [42,45]. For all the other sensitivity parameters we see much lower impacts. Even if they induce a strong change in the system structure in our modeling, we achieve a wide variety of scenarios at roughly the same system costs.

The analysis of the structural changes shows a number of interesting effects on individual technologies. In particular, technology cost assumptions and restrictions on grid expansion between the regions have a large influence on the portfolio of installed capacities of fossil power plants in BTH and of renewable power plants in Inner Mongolia. High VRE technology costs would strongly influence the installation of CSP, PV, onshore wind and lithium-ion batteries in Inner Mongolia. Low storage costs will particularly promote the installation of lithium-ion batteries and hydrogen storage. The installation of onshore wind in Inner Mongolia is highly influenced by the VRE costs, which also have an impact on the expansion of compressed air energy storage. Higher costs for VRE and storage technologies would promote the installation of CSP due to increased cost competitiveness. The restriction of grid expansion would have the largest influence on the installation of offshore wind turbines, lithium-ion batteries and CCGT in the BTH region.

Furthermore, restricting the curtailment ratio to 5% affects the installed capacities of gas turbines and lithium-ion batteries in the BTH region and on the installation of CSP, PV, and onshore wind in Inner Mongolia. Although a strong restriction of curtailment is very likely to lead to an expansion of storages (see also [43]) it also results in higher operating hours for coal, GT, biomass and CSP and at the same time rather lower FLH for storage technologies.

Many research questions are still open: The consideration of additional sector coupling options such as flexible direct or indirect electrification (via power-to-gas), demand side management in industry or the use of cost-effective energy storage in the heating and gas have an impact on the results of such system modelling, particularly with regard to storage technologies [40]. Future changes in load profiles could have additional effects and should be investigated. Furthermore, we have not considered the combined impact of individual cost changes on the configuration and operation of the system. The robustness of the results presented here is also challenged by the fact that the linear optimization approach is susceptible to penny switching effects in technology selection, which has already been discussed elsewhere (e.g., [46]). On the other hand, our scenario analyses result in a large optimization plateau that presents many technologies as valid solutions, thus limiting the risk of costly wrong decisions at the political level. Last but not least, apart from the generation side, exploring carbon reduction potentials from the demand side with options such as carbon cap, cap-and-trade, and carbon tax also play a vital role in achieving a low carbon energy system (see e.g., [47–51]).

## 6. Conclusions

We applied a linear approach to minimize system costs in order to analyze the deployment of various technologies of power generation, storage and grid transmission in a low-carbon scenario at

hourly resolution. We also looked at the future role of electric vehicles in the integration of VRE into the regional power supply system. In addition, the current short- or medium-term development targets for renewable energies were integrated into the analysis of a low-carbon power supply in the long-term future. A sensitivity analysis of selected parameters addresses the high level of uncertainty associated with the unclear cost development of new technologies and possible constraints. The optimization results illustrate the possible infrastructural needs of the future power system, which differ significantly in the metropolitan region and the supply region. The hourly dispatch shows the interactions between different technologies in balancing power generation and demand as VRE market penetration increases and additional electricity is needed for the electrification of the heating and transport sectors.

The optimization results show that under the set system constraints, the share of renewable energy in terms of installed capacity and annual electricity generation would increase significantly, leading to an immediate reduction in CO<sub>2</sub> emissions from power generation in both regions. With the further expansion of renewable energies in the power systems, the amount of curtailed power also increases. Therefore, much more flexible technologies and operating strategies need to be implemented in the medium to long term.

According to the optimization results, the marginal costs of electricity generation would increase until 2040 in all modeled municipalities and provinces. The better solar and wind resources in Inner Mongolia result in lower marginal costs compared to the BTH region. Even if the overall share of fossil generation declines sharply, under the assumed CO<sub>2</sub> emission path, a significant installed fossil power plant capacity in the BTH region would serve as a backup in the long-term. In contrast, the installed fossil power plant capacity in Inner Mongolia could be largely replaced by 2050. The results for the metropolitan region are more sensitive in comparison to the supply region if future import corridors are restricted. In all cases considered, however, the combination of spatial and temporal balancing measures is able to cover the hourly electricity demand with a large share of variable renewable energy such as PV and wind. The relevance of grid expansion and electricity imports illustrates the necessity of integrated regional planning to deal with the unbalanced distribution of electricity demand and renewable resources at minimum cost. The modeling also provides evidence that such regional cooperation reduces the overall curtailment, leading to a more efficient energy system.

The sensitivity analysis revealed that variations in input parameters—apart from storage—have little impact on the total system costs, even if they have significant effects on the other analyzed parameters (capacity and generation/FLH). This means that different system layouts promise a feasible renewable energy system for the interconnected regions at similar costs.

Due to the limited hinterland, the future decarbonization of the energy system in metropolitan regions generally poses a major challenge. The significantly unbalanced distribution of renewable resources and load demand in China further increases the dependence of the future low-carbon energy system on the expansion of transmission corridors. Regionally integrated modeling between RE-rich regions and demand centers provide comprehensive evidence of how renewable power supply could be implemented, and first estimates of required future investments in various power generation, storage and transmission technologies. In addition to setting an overall regional cap on CO<sub>2</sub> emissions, the introduction of CO<sub>2</sub> certificate prices is proving to be an effective climate policy to reduce the operation of fossil-fuel power plants and further promote the expansion of VRE in the power system.

**Supplementary Materials:** The following are available online at <http://www.mdpi.com/1996-1073/13/12/3042/s1>, Table S1: Literature review of scenario analysis for the Chinese power sector, Table S2: Assumed market shares for modes and vehicle types under the renewable and import scenario (RIS) in study regions, etc. Figure S1: Maximum installable wind power capacity per km<sup>2</sup> over 4 m/s threshold in China, Figure S2: Maximum installable PV capacity per km<sup>2</sup> in China, etc..

**Author Contributions:** Conceptualization, M.X.; M.W.; T.P.; S.S. and Y.S.; data curation, M.X.; M.W. and Y.S.; formal analysis, M.X.; M.W.; T.P.; S.S. and Y.S.; methodology, M.X.; M.W.; T.P.; S.S. and Y.S.; software, M.X.; M.W. and Y.S.; supervision, M.W.; T.P.; S.S. and Y.S.; validation, M.X.; M.W.; T.P.; S.S. and Y.S.; visualization, M.X.; M.W.; T.P.; S.S. and Y.S.; writing—original draft preparation, M.X.; writing—review and editing, M.X.; M.W.; T.P.; S.S. and Y.S. All authors have read and agreed to the published version of the manuscript.

**Funding:** This research received no external funding.

**Conflicts of Interest:** The authors declare no conflict of interest.

## References

1. OECD. *The Metropolitan Century: Understanding Urbanisation and Its Consequences*; OECD: Paris, France, 2015.
2. China Research Institute of Academy of Macroeconomic Research/NDRC; China National Renewable Energy Center. *China Renewable Energy Outlook 2017*; China Research Institute of Academy of Macroeconomic Research/NDRC; China National Renewable Energy Center: Beijing, China, 2017.
3. NEA. *Renewable Portfolio Standard Policy (RPS)*; National Energy Administration: Beijing, China, 2016.
4. Xiong, W.; Wang, Y.; Mathiesen, B.V.; Zhang, X. Case study of the constraints and potential contributions regarding wind curtailment in Northeast China. *Energy* **2016**, *110*, 55–64. [\[CrossRef\]](#)
5. NDRC. *13th National Five-Year Plan for Power Development*; National Development and Reform Commission: Beijing, China; National Energy Board: Ottawa, ON, Canada, 2016.
6. National Development and Reform Commission (NDRC). *13th Five-Year Plan for Beijing-Tianjin-Hebei Region Renewable Energy Development*; National Development and Reform Commission (NDRC): Beijing, China, 2016.
7. UN. *World Urbanization Prospects*; Department of Economic and Social Affairs, Population Division: New York, NY, USA, 2014.
8. The Situation of Wind Power Operation of 2017 in China. 2018. Available online: [http://www.nea.gov.cn/2018-02/01/c\\_136942234.htm](http://www.nea.gov.cn/2018-02/01/c_136942234.htm) (accessed on 11 February 2019).
9. He, G.; Avrin, A.-P.; Nelson, J.H.; Johnston, J.; Mileva, A.; Tian, J.; Kammen, D.M. SWITCH-China: A Systems Approach to Decarbonizing China's Power System. *Environ. Sci. Technol.* **2016**, *50*, 5467–5473. [\[CrossRef\]](#) [\[PubMed\]](#)
10. Li, Y.; Lukszo, Z.; Weijnen, M. The impact of inter-regional transmission grid expansion on China's power sector decarbonization. *Appl. Energy* **2016**, *183*, 853–873. [\[CrossRef\]](#)
11. Cheng, Y.; Zhang, N.; Kirschen, D.S.; Huang, W.; Kang, C. Planning multiple energy systems for low-carbon districts with high penetration of renewable energy: An empirical study in China. *Appl. Energy* **2020**, *261*, 114390. [\[CrossRef\]](#)
12. Yi, B.-W.; Xu, J.-H.; Fan, Y. Coordination of policy goals between renewable portfolio standards and carbon caps: A quantitative assessment in China. *Appl. Energy* **2019**, *237*, 25–35. [\[CrossRef\]](#)
13. Burandt, T.; Xiong, B.; Löffler, K.; Oei, P.-Y. Decarbonizing China's energy system—Modeling the transformation of the electricity, transportation, heat, and industrial sectors. *Appl. Energy* **2019**, *255*, 113820. [\[CrossRef\]](#)
14. Zhang, N.; Hu, Z.; Shen, B.; He, G.; Zheng, Y. An integrated source-grid-load planning model at the macro level: Case study for China's power sector. *Energy* **2017**, *126*, 231–246. [\[CrossRef\]](#)
15. Liu, H.; Andresen, G.B.; Greiner, M. Cost-optimal design of a simplified highly renewable Chinese electricity network. *Energy* **2018**, *147*, 534–546. [\[CrossRef\]](#)
16. Ye, L.-C.; Lin, H.X.; Tukker, A. Future scenarios of variable renewable energies and flexibility requirements for thermal power plants in China. *Energy* **2019**, *167*, 708–714. [\[CrossRef\]](#)
17. Gils, H.C.; Scholz, Y.; Pregger, T.; de Tena, D.L.; Heide, D. Integrated modelling of variable renewable energy-based power supply in Europe. *Energy* **2017**, *123*, 173–188. [\[CrossRef\]](#)
18. Zappa, W.; Junginger, M.; van den Broek, M. Is a 100% renewable European power system feasible by 2050? *Appl. Energy* **2019**, *233–234*, 1027–1050. [\[CrossRef\]](#)
19. Scholz, Y.; Gils, H.C.; Pietzcker, R.C. Application of a high-detail energy system model to derive power sector characteristics at high wind and solar shares. *Energy Econ.* **2017**, *64*, 568–582. [\[CrossRef\]](#)
20. Cebulla, F.; Naegler, T.; Pohl, M. Electrical energy storage in highly renewable European energy systems: Capacity requirements, spatial distribution, and storage dispatch. *J. Energy Storage* **2017**, *14*, 211–223. [\[CrossRef\]](#)
21. Luca de Tena, D.; Pregger, T. Impact of electric vehicles on a future renewable energy—Based power system in Europe with a focus on Germany. *Int. J. Energy Res.* **2018**, *42*, 2670–2685. [\[CrossRef\]](#)
22. Gils, H.C.; Pregger, T.; Flachsbarth, F.; Jentsch, M.; Dierstein, C. Comparison of spatially and temporally resolved energy system models with a focus on Germany's future power supply. *Appl. Energy* **2019**, *255*, 113889. [\[CrossRef\]](#)

23. Fichter, T. Long-term Capacity Expansion Planning with Variable Renewable Energies—Enhancement of the REMix Energy System Modelling Framework. Ph.D. Thesis, University of Stuttgart, Stuttgart, Germany, 2017.
24. Xiao, M.; Simon, S.; Pregger, T. Scenario analysis of energy system transition—A case study of two coastal metropolitan regions, eastern China. *Energy Strategy Rev.* **2019**, *26*, 100423. [[CrossRef](#)]
25. NASA. *Surface Radiation Budget (SRB) Release-3.0 Data Sets*; National Aeronautics and Space Agency NASA: Washington, DC, USA, 2012.
26. Scholz, Y. Renewable Energy Based Electricity Supply at Low Costs: Development of the REMix Model and Application for Europe. Ph.D. Thesis, University of Stuttgart, Stuttgart, Germany, 2012.
27. Stetter, D. Enhancement of the REMix Energy System Model: Global Renewable Energy Potentials, Optimized Power Plant Siting and Scenario Validation. Ph.D. Thesis, University of Stuttgart, Stuttgart, Germany, 2014.
28. NDRC. *13th National Five-Year Plan. for Geothermal Development*; National Development and Reform Commission: Beijing, China; National Energy Administration: Beijing, China; National Ministry of Land and Resources: Beijing, China, 2017.
29. National Energy Administration. *Guidance for Renewable Energy Development during 13th Five-year Plan Period (2017–2020)*; National Energy Administration: Beijing, China, 2017.
30. Ministry of Energy. *13th Five-year Plan for Biomass Development*; Ministry of Energy: Beijing, China, 2016.
31. Government of Hebei Province. *13th Five-Year Plan for Energy Development in Hebei Province*; Government of Hebei Province: Hebei, China, 2017.
32. Solar Thermal Expo. *The CSP Development Targets in Eight Provinces Will Reach 9.31 GW by 2020*; Solar Thermal Expo: Beijing, China, 2017.
33. Platts. *World Electric Power Plants Database*; Platts: London, UK, 2015.
34. China National Renewable Energy Center; China Research Institute of Academy of Macroeconomic Research/NDRC. *China Renewable Energy Outlook 2018*; China National Renewable Energy Center: Beijing, China, 2018.
35. Cao, K.-K.; Pregger, T.; Scholz, Y.; Gils, H.C.; Nienhaus, K.; Deissenroth, M.; Schimeczek, C.; Krämer, N.; Schober, B.; Lens, H.; et al. *Analysis of Infrastructural Options to Integrate Renewable Energies in Germany and Europe Considering Security of Supply (INTEEVER)*; Federal Ministry for Economic Affairs and Energy: Berlin, Germany, 2019.
36. IEA. *World Energy Outlook 2018*; International Energy Agency: Paris, France, 2018.
37. Teske, S.; Giurco, D.; Morris, T.; Nagrath, K.; Mey, F.; Briggs, C.; Dominish, E.; Florin, N. *Achieving the Paris Climate Agreement Goals: Global and Regional 100% Renewable Energy Scenarios to Achieve the Paris Agreement Goals with Non-Energy GHG Pathways for + 1.5 °C and + 2 °C*; Springer: Cham, Switzerland, 2019.
38. Yan, L. *Multi-Resolution Emission Inventory for China; v.1.0*, MEIC Database; Tsinghua University: Beijing, China, 2012.
39. Luderer, G.; Pietzcker, R.C.; Carrara, S.; de Boer, H.S.; Fujimori, S.; Johnson, N.; Mima, S.; Arent, D. Assessment of wind and solar power in global low-carbon energy scenarios: An introduction. *Energy Econ.* **2017**, *64*, 542–551. [[CrossRef](#)]
40. Schlachtberger, D.P.; Brown, T.; Schäfer, M.; Schramm, S.; Greiner, M. Cost optimal scenarios of a future highly renewable European electricity system: Exploring the influence of weather data, cost parameters and policy constraints. *Energy* **2018**, *163*, 100–114. [[CrossRef](#)]
41. Kittner, N.; Lill, F.; Kammen, D.M. Energy storage deployment and innovation for the clean energy transition. *Nat. Energy* **2017**, *2*, 17125. [[CrossRef](#)]
42. Schmidt, O.; Hawkes, A.; Gambhir, A.; Staffell, I. The future cost of electrical energy storage based on experience rates. *Nat. Energy* **2017**, *2*, 17110. [[CrossRef](#)]
43. Cebulla, F. Storage Demand in Highly Renewable Energy Scenarios for Europe: The Influence of Methodology and Data Assumptions in Model-Based Assessments. Ph.D. Thesis, University of Stuttgart, Stuttgart, Germany, 2017.
44. Chen, X.; Lv, J.; McElroy, M.B.; Han, X.; Nielsen, C.P.; Wen, J. Power System Capacity Expansion Under Higher Penetration of Renewables Considering Flexibility Constraints and Low Carbon Policies. *IEEE Trans. Power Syst.* **2018**, *33*, 6240–6253. [[CrossRef](#)]
45. Matteson, S.; Williams, E. Residual learning rates in lead-acid batteries: Effects on emerging technologies. *Energy Policy* **2015**, *85*, 71–79. [[CrossRef](#)]

46. Trutnevyte, E. Does cost optimization approximate the real-world energy transition? *Energy* **2016**, *106*, 182–193. [[CrossRef](#)]
47. Pourakbari-Kasmaei, M.; Lehtonen, M.; Contreras, J.; Mantovani, J.R.S. Carbon Footprint Management: A Pathway Toward Smart Emission Abatement. *IEEE Trans. Ind. Inform.* **2020**, *16*, 935–948. [[CrossRef](#)]
48. Liu, Y.; Zhang, N.; Kang, C.; Xia, Q.; Wu, H.; Chen, Z. Impact of Carbon market on China's electricity market: An equilibrium analysis. In Proceedings of the 2017 IEEE Power Energy Society General Meeting, Chicago, IL, USA, 16–20 July 2017; pp. 1–5.
49. Pourakbari-Kasmaei, M.; Mantovani, J.R.S.; Rashidinejad, M.; Habibi, M.R.; Contreras, J. Carbon footprint allocation among consumers and transmission losses. In Proceedings of the 2017 IEEE International Conference on Environment and Electrical Engineering and 2017 IEEE Industrial and Commercial Power Systems Europe (EEEIC/I CPS Europe), Milan, Italy, 6–9 June 2017; pp. 1–6.
50. Yang, X.; Hou, Y. The Effects of Energy Policies on Stimulating Clean Electricity Production of Individual Suppliers. In Proceedings of the 2019 IEEE Power Energy Society Innovative Smart Grid Technologies Conference (ISGT), Washington, DC, USA, 17–20 February 2019; pp. 1–5.
51. Mollahassani-Pour, M.; Rashidinejad, M.; Pourakbari-Kasmaei, M. Environmentally constrained reliability-based generation maintenance scheduling considering demand-side management. *IET Gener. Transm. Distrib.* **2019**, *13*, 1153–1163. [[CrossRef](#)]



© 2020 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<http://creativecommons.org/licenses/by/4.0/>).