

Article

# Analysis of Techno-Economic-Environmental Suitability of an Isolated Microgrid System Located in a Remote Island of Bangladesh

Hasan Masrur <sup>1,\*</sup> , Harun Or Rashid Howlader <sup>1</sup>, Mohammed Elsayed Lotfy <sup>1,2</sup>,  
Kaisar R. Khan <sup>3</sup>, Josep M. Guerrero <sup>4</sup>  and Tomonobu Senjyu <sup>1</sup> 

<sup>1</sup> Department of Electrical & Electronics Engineering, Faculty of Engineering, University of the Ryukyus, 1 Senbaru, Nishihara-cho, Nakagami, Okinawa 903-0213, Japan; h.h.howlader@ieee.org (H.O.R.H.); lotfyico2010@gmail.com (M.E.L.); b985542@tec.u-ryukyu.ac.jp (T.S.)

<sup>2</sup> Zagazig University, Zagazig 44519, Egypt

<sup>3</sup> Eversource Energy, Southborough, MA 01772, USA; kaisar@knights.ucf.edu

<sup>4</sup> Department of Energy Technology, Aalborg University, 9220 Aalborg, Denmark; joz@et.aau.dk

\* Correspondence: hmasrur@gmail.com

Received: 11 March 2020; Accepted: 1 April 2020; Published: 4 April 2020



**Abstract:** Following a rise in population, load demand is increasing even in the remote areas and islands of Bangladesh. Being an island that is also far from the mainland of Bangladesh, St. Martin's is in need of electricity. As it has ample renewable energy resources, a renewable energy-based microgrid system seems to be the ultimate solution, considering the ever-increasing price of diesel fuel. This study proposes a microgrid system and tests its technical and economic feasibility in that area. All possible configurations have been simulated to try and find the optimal system for the island, which would be eco-friendly and economical with and without considering renewable energy options. The existing power supply configuration has also been compared to the best system after analyzing and investigating all technical and economic feasibility. Sensitivity and risk analysis between different cases provide added value to this study. The results show that the current diesel-based system is not viable for the island's people, but rather a heavy burden to them due to the high cost of per unit electricity and the net present cost. In contrast, a PV /Wind/Diesel/Battery hybrid microgrid appeared to be the most feasible system. The proposed system is found to be around 1.5 times and 28% inexpensive considering the net present cost and cost of energy, respectively, with a high (56%) share of renewable energy which reduces 23% carbon dioxide.

**Keywords:** techno-economic-environmental feasibility; renewable energy-based microgrid; simulation and optimization; sensitivity, emission and risk analysis

## 1. Introduction

St. Martin's (20037.9' N, 92019.8 E) is the only coral island in Bangladesh. It is situated on the north-eastern side of the Bay of Bengal, the ocean. Cox's Bazar-Teknaf peninsula is about 9 km south of this island, in the southernmost part of Bangladesh. According to the Köppen climate classification, it belongs to the group of type A climates. One survey done in 2004 by the Local Government Engineering Department (LGED) found that around 8000 people resided here. This number goes up in the tourist season, as it is one of the most beautiful places in Bangladesh. The island has no grid connection, and it seems like there are less possibilities to connect in the near future by the government as well. Few diesel-fueled generators have been installed by the local authorities and by general people to meet their power demand, which is not enough at all. They are also not functioning properly. As natural gas supply is also not available, individuals meet their basic electricity demand plus cooking mainly

through lamp oil (kerosene), coconut palm, leaves, and/or by different biomass plants. Since it is in the coastal region, wind is pretty much available almost all the time at a decent speed. Solar energy is also available here [1].

Though more than 8000 individuals from 1220 families are living in St. Martin's Island, not many of them are getting electricity. Besides, more than 32,000 travelers consistently visit this Island from home and abroad. There are around 120 lodgings and bungalows for the convenience of the sightseers. In 1985, the Power Development Board, Bangladesh (PDB) set up a huge generator (120 kVA) to give power to St. Martin's Island which had been completely harmed by the typhoon season of 1991 [2]. Ever since then, there has been no power supply given from the mainland by the government. A couple of privately settled generators and a couple of solar panels are currently the main sources of power in St. Martin's. Thus, there is still no progression in power and most of the inhabitants are presently out of power.

As indicated by the Bangladesh Bureau of Statistics (BBS) [3], just 26.4% of its population is getting power, and just for 4 hours (6:00 p.m. to 10:00 p.m.). They use diesel generators from neighborhood providers, and some Solar Home Systems (SHS) built up by different rustic advancement associations and NGOs. The number of homes with SHS installed is also not much, only 50, where every one of them are utilizing just a single 10W dc bulb. Not more than 100 generators have been claimed by various lodgings, bungalows, and a few other people for essentially providing power to sightseers, and a couple for neighborhood occupants. Figure 1 shows the outline of this island.

The electricity that they use is very expensive, and costs more than 0.59 US Dollars (\$) for every unit of power. Sometimes it goes up to \$6 for utilizing one light and one fan just for 4 hours each day, which is really a burden for these people. This island is more than 17 km away from Teknaf, Bangladesh. Thus, electricity from the grid through to the mainland is not conceivable even in future, and at present there is also no such indication of this nor any effort from the government's side. Though power transmission may be possible by utilizing the submarine link, it is way too expensive to establish. Considering the poor economic status of the inhabitants, the frequent increase in diesel prices, as well as GHG emission from diesel generators suggests that these arrangements should not be fully relied on. The reliance on wood and charcoal of some residents for fuel has also unavoidably prompted deforestation and desertification because of the absence of re-manor and soil restoration plans. On the other hand, St. Martin's Island has abundant energy sources, such as sunlight, wind, and biomass. Thus, a hybrid microgrid power system (HMPS) utilizing renewable energy resources could work out an achievable arrangement of this power predicament of the people of this beautiful Island. Furthermore, it can be an example for the policymakers of Bangladesh and abroad to include such systems as a national energy supply unit within a regulatory framework, which can be learned from international legislation regarding microgrids [4].

The overall objective of this study was to propose a renewable energy-based microgrid system in order to meet the load demand of St. Martin's Island by running a technical and economic feasibility analysis. To achieve this objective, the following tasks were performed: (a) Evaluation and techno-economic analysis of the existing diesel-only electricity system. (b) Simulation of all possible combinations of the electricity system, including renewable energy sources, and finding out the best optimal system. (c) Optimization, sensitivity, risk, and emission analyses of the newly found best system.

This paper is organized in the following: Section 1 shows the introductory part, which includes the background of the study, problem statement, and objectives of this study. Section 2 describes the literature review, while Section 3 discusses the research methodology and defines the whole system parameters. Section 4 discusses the simulation results, whereas the last Section 5 depicts the conclusion, along with future guidelines.




Figure 1. Map of St. Martin's Island [5].

## 2. Literature Review

There are many types of simulation and optimization software that carry out research in terms of design and development of hybrid energy systems, like Hybrid2, HOGA, RETScreen, HOMER, TRANSYS, Aries, SOLES, RAPSYSM, HySym, and INSEL. Among all these tools, Hybrid Optimization of Multiple Energy Resources (HOMER) seems to be used most often [6]. This study also adopted HOMER to perform our analysis.

There have been many significant works done by researchers around the world on the Hybrid power system with renewable energy, which are either off-grid [7–25] or grid-connected [26–33]. In [7], Groppi et al. focused on the hybrid storage (battery plus hydrogen) system while planning a smart energy system to ensure economic and environmental benefits. However, they did not explain the technical feasibility of their proposed system. Article [8] discusses a methodology to integrate a high share of renewable energy in an island using PLEXOS software, which was cheaper (2.5%) than the fossil fuel-based system and met 78.1 % of the final electricity demand. No risk or sensitivity analyses were performed, however, which are necessary to ensure the applicability of the planned power system. In a techno-economic feasibility study for a Chinese household [9] with a hybrid wind/PV/battery system by HOMER, the effect of ambient temperatures and variation of loads were taken into account. They also assumed the load profile. Much emphasis was given to the PV tilt angle. They also presented economic, sensitivity, and PV tilt analyses of the system. They came up with a system which reduced the Net Present Cost (NPC) by about 10% for the same levelized Cost of Energy (COE) compared to other hybrid combinations. A microgrid system for a health clinic with a 31.6 kW aggregated load comprised of 6 kW PV modules, 80 batteries (225 Ah and 6 V), and a 3 kW inverter seemed to be the most techno-economic in the work of Al-Karaghoul and Kazmerski [10] in southern Iraq. However, this study did not discuss the susceptibility of renewable energy sources

to cost. A comprehensive feasibility study was performed by Abdirahman et al. [11] in Somaliland's urban places where a modern electricity grid is yet to be established. Their optimization and sensitivity analysis showed that it was more economically viable than the present "business-as-usual" scenario to implement a Renewable energy-based system in Somaliland. They found an almost 30% reduction in COE, followed by a 25% decrease in total net present cost and up to 58% achievement in renewable energy penetration for their proposed PV-wind-diesel-battery hybrid system. They also used HOMER for their analysis. However, they only showed the impact of load demand in sensitivity analyses without considering other factors, like diesel price, wind speed, and solar radiation. Almost the same type of study in three villages of Nigeria showed the dominance of an RE-based system over a locally supplied, stand-alone, diesel-only system [12]. The author claimed that to establish a decent electricity supply for the rural clinics of those villages with a daily energy usage of 15.5 kWh and 2.75 kW peak demand, there was no other way but to implement a hybrid energy system without the presence of a main grid electricity supply. According to the optimization and sensitivity analysis, they found out that there was a more significant fluctuation in the COE due to the change of solar radiation at each site than the change in diesel price. They did not explain the sensitivity analysis broadly.

Researchers in [13] investigated a PV-diesel-battery hybrid system in a remote village of Saudi Arabia compared to a diesel-only system. They found out that diesel-only plants were becoming more uneconomical due to the increase in fuel prices, and recommended establishing a hybrid system with 20% of solar PV penetration. Ibrahim et al. [14] came up with a Wind/PV-solar Hybrid Energy System in Chennai, India for a Global System for Mobile communication (GSM)/Code-division multiple access (CDMA) system, which is a type of mobile telephone base station. The authors claimed a 70%–80% reduction of fuel costs, likening it to the old diesel-only system achieving an emission drop in CO<sub>2</sub>, and other harmful particles as well. Akella and Sharma [15] modeled an integrated, renewable-based power system with a micro-hydro, solar PV, wind turbine, and battery to meet the 808MWh/yr load demand. The optimized system analyzed through LINDO software showed that the system would only become feasible if the optimizing power factor, known as an electric power delivery factor, exists in a range of 1.0–0.75 for the fulfilment of a 687 MWh/yr load demand. Kumaravel and Ashok [16] presented an alternative hybrid power system with Solar PV, biomass, and pico-hydel for a present pico-hydel/diesel system, which would be more economically viable. Zoulias and Lymberopoulos [17] proved the technical feasibility of hydrogen technologies, which would replace the conventional diesel-based generators and/or batteries, but the economic viability depended on several conditions regarding reduction of cost. Mohammed and khatib [18] developed an optimization algorithm for obtaining the sizing of PV-wind-diesel system based on iterative simulation. Later, they validated it by conducting a HOMER optimization analysis and concluded claiming the superiority of the proposed algorithm in terms of accuracy level. Article [19] analysed a CHP-PV-based microgrid in terms of microturbine efficiency of the CHP unit and its overall economic feasibility. It investigated the impact of variations in load changes and fuel prices without discussing the role of other sensitive parameters, such as solar irradiation.

A very interesting techno-economic optimization study done by Rajkumar et al. [20] used an adaptive neuro-fuzzy interference system to gratify the Loss of Power Supply Probability (LPSP), obtaining the lowest COE. They obtained 96% accuracy after comparing the system to HOMER and HOGA tools. Diaf et al. [21] came up with a hybrid PV-wind system and presented a reliable and economic model based on LPSP and a levelized cost of energy (LOCE). They said that without a large battery capacity, almost 30% of energy output becomes unused if one wants to obtain fullest RE penetration. They also suggested making system device choices carefully as it affects the optimal sizing of the system. Ekren et al. in [22] carried out research where they found that the optimum area of solar PV (3.95 m<sup>2</sup>), wind (29.4 m<sup>2</sup>), and battery capacity was around 31.92 kWh, which costed 37,033.9 USD. They argued that for a distance of more than 4817 km between the hypothetical GSM base station and national grid, installing a hybrid power system would be more economical. Maouedj et al. [23] tested a PV-wind hybrid experimental system in Adrar, Nigeria with a timeframe of 10 days. The excess

electricity was stored in a battery bank, which was produced by the system in the daytime. They observed that solar radiation had a greater contribution than wind power technology by 69%, and that batteries were charged most within one hour in the afternoon due to the high availability of wind speed and solar power. Bekele et. al [24] studied the stand-alone PV-wind microgrid system application in Ethiopia. The author considered a community comprising 1200 people. He selected the wind turbine, PV, and battery and compared this hybrid system to existing hydropower systems. He suggested that as there was less wind potential, the PV-diesel-battery system would make an excellent energy system for the people. In Malaysia, a feasibility study of a photovoltaic, battery, and wind-based energy system of island resorts by Ashourian [25] showed their supremacy over a diesel-alone system in terms of NPC, COE, and renewable fraction. The proposed system appears to be green, environmentally friendly, and pollution-free.

In light of the above discussion, the renewable energy-oriented microgrid system can be classified into several categories, which are: (a) an off-grid stand-alone hybrid system, (b) a grid-tied hybrid system, (c) a system including generators, and (d) a system excluding generators.


While some researchers emphasize the technical aspects of a system, others focus on economic analysis. Almost everyone investigated the emission prospects. Many scholars tried to find optimal sizing of the proposed or existing power system using various noteworthy algorithms, like Monte Carlo, Particle Swarm Optimization, and the genetic algorithm, which mostly happened to be probabilistic, rather than a deterministic approach. Some studies also focused on the PV Array's and wind turbine's technical specifications by adding a tracking system and varying the hub height, respectively. Other properties of energy resources were also varied. Besides wind and solar energy, while doing simulations in HOMER, the run-off hydro, hydrogen tank, flywheel, reformer, and electrolyzer were considered for some studies. The cycle following the dispatch strategy has been discussed in almost all studies. Generators are allowed to operate concurrently in multiple numbers. Though there are various kinds of software and tools available to model and analyze this type of system, HOMER appears to be the one most widely used by researchers.

To the author's best knowledge, very few researchers considered all the possible variation sensitive parameters applicable to HMPS, especially for remote islands. Again, reliability and risk analysis was found to be very rare in the reviewed literature, specifically in studies related to remote islands. Hence, the contributions of this study are as follows:

- Detailed techno-economic-environmental benefits of the proposed hybrid microgrid are presented in comparison to the existing power system of the island.
- The impact of four variables, including load demand, wind speed, solar radiation, and diesel price on HMPS is examined, which are sufficient for a sensitivity analysis.
- A thorough risk assessment of the proposed system is performed using "scenario" analysis.

### 3. Research Methodology

In order to achieve the objectives, some steps were taken into account, which are depicted in Figure 2. A pre-feasibility study of the selected site, that is, St. Martin's island, was performed, which included a load demand estimation existing power system assessment, meteorological data and resource evaluation, and economic parameters & system constraint selection. After that, techno-economic simulation and optimization analyses were carried out. Based on the result, a comprehensive post-feasibility study was performed to undertake the sensitivity, risk, and emission analyses of the proposed hybrid system compared to the base case.



**Figure 2.** Steps of overall research methodology.

### 3.1. Site Load Estimation

For this study, a municipal of 770 families and 30 different types of shops was considered. The primary loads were as follows: three energy-efficient lamps (compact fluorescent bulb, 15 W each), one fan (ceiling fan, 50 W), one television (TV, 80 W), and one refrigerator (80 W) for every family. The load demand is provided in Figure 3. Some daily arbitrariness of 20% and 15% noise from time step to time step was added. Note that the time step chosen was 60 min. The resultant annual peak load was summed up to be 324 kW, and the primary load to be 2792 kWh/day.




Figure 3. Load demand for each hour.

### 3.2. Solar Energy

Monthly averaged global radiation data was taken from the National Renewable Energy Laboratory (NREL), which is indicated in the clearness index from the latitude and longitude information and has been introduced at the selected site [34]. HOMER created the synthesized 8760 hourly values for a year using the Graham algorithm. Figure 4 illustrates that solar radiation is high from February to May. The average annual clearness index is 0.4455, and the average daily radiation is 4.55 kWh/m<sup>2</sup>/day.




Figure 4. Solar radiation data throughout the year.

### 3.3. Wind Energy

The wind data for this study shown in Figure 5 was also taken from the NREL [34]. The wind turbine is designed in such a way that it alters kinetic energy into dc or ac electricity, which depends on the specific power curve, and this curve is the graph of output power versus wind speed at hub height. It was considered that the lifetime is 20 years and the hub height of the turbine is 24 m. No ambient temperature effect was selected.

According to some reports, St. Martin’s altitude above sea level is 7.62 m. Along with this, the default anemometer height (10 m) and surface roughness length (0.01 m) was too considered for this study. The anemometer height is the height above the ground at which the wind speed is measured.




Figure 5. Power curve of wind turbine.

### 3.4. Diesel

Being the only energy source for the generators of this island, diesel (price) plays a vital role in proposing or modeling any power system. According to BPC, the diesel price in Bangladesh is currently about US\$ 0.81/L, which is not fixed [35]. Over the years, this price has continuously fluctuated. Due to the irregular behavior of diesel fuel prices, any diesel-based microgrid project can be accelerated or delayed, and even canceled, as it is directly related to Net Present Cost (NPC) and Cost of Energy (COE) for the production of electricity per unit.

### 3.5. Hybrid System Components

In this study, all critical components of the hybrid energy system were considered, specifically PV panels, wind turbines, diesel generator, batteries, and converters. For economic analysis, the project lifetime, annual interest rate, the number of units to be used, system fixed cost, and capacity shortage penalty have been defined. The initial capital costs, replacement, and O & M costs and operating hours were to be assigned in HOMER to simulate the system. All of the system component parameters are presented in Table 1.

Table 1. Hybrid system component values.

Component Parameters	Values	Component Parameters	Values
<i>Solar PV [36]</i>		<i>Backup Generator [37]</i>	
Capital Cost	\$447	Sizes considered	30, 200 and 500 kW
Replacement Cost	\$400	Maximum Load Ratio	25%
O&M Cost	\$0.50	Initial cost per unit	\$330/kW
Lifetime	20 years	Replacement cost	\$330/kW
Sizes considered	50, 100, 200 and 250 kW	O&M cost	\$0.5/h
Derating Factor	80%	Lifetime	15,000 hrs
Slope	20.632 deg	<i>Diesel Parameters [35]</i>	
<i>Converter [38]</i>		Diesel	Fuel
Capital Cost	\$300/kW	Price	\$ 0.81/L
Maintenance Cost	\$10/year	Lower heating value	43.2 MJ/kg
Sizes consideration	24, 30, 36, 42 and 48 kW	Density	820.00 kg/m <sup>3</sup>

Table 1. Cont.

Efficiency	90%	Carbon content	88.0%
Lifetime	15 years	Sulfur content	0.4%
Inverter can parallel with AC	Yes	Wind turbine [39]	
Battery[40]		Model	Fuhrländer FL 30
Model	Surrete S6CS25P	Rated Power	30 kW (AC)
String	10	Capital Cost	\$70,000
Nominal capacity	4 V	Replacement Cost	\$65,000
State of charge	40%	Lifetime	20 years
Capital/replacement Cost (\$/pc)	1259/1100	Number of turbine considered	0~10
O&M cost	0.02 (\$/yr)		
Lifetime throughput	10,569 (kWh)		

The cost of the flat plate PV module, including installation, was considered based on the price of Grameen Shakti [41], a leading solar PV supplier of Bangladesh. The lifetime of the modules was taken as 20 years, and 50, 100, 200, and 250 kW PV modules were considered. The temperature effect was also considered in the simulation. For the hybrid system, the Fuhrländer wind turbine was considered. HOMER simulated it for 0, 1, 2, 3, 5, and 10 turbines. Three generators rated 500 kW, 200 kW, and 30 kW were used to model the hybrid system. The fuel used in HOMER was modeled by a linear curve characterized by a slope and intercept at no load. The slope and the intercept of the curve were 0.2440 L/h/kW and 0.0140 L/h/kW, respectively. The price of a 34 kW Genset is given as the input for both generators based on the data of Tokai Power Products Ltd., Bangladesh [37]. According to the Bangladesh Petroleum Corporation, the price of diesel in Bangladesh is US\$0.81/L now. This study tried to put the real value of other parameters as well in order to get a real analysis. The Generic Surrete S6CS25P battery was utilized in the hybrid system. Quite a large number of batteries are given as input for simulation, and each battery costs 638 US dollars. The specifications are shown in Table 1. A converter was required to convert AC-DC or DC-AC. In this study, one 100 kW converter with a 15-year lifetime was selected. The estimated capital and replacement cost was \$300.00 with no O&M cost. The inverter and rectifier input efficiency was the same (85%) and worked parallel with the AC generator.

### 3.6. Assumptions and Limitations

HOMER only considered the cost regarding capital, replacement, and O&M costs, which is very straightforward and simplified. The consumer load demand was also synthesized. In reality, the cost pattern and customer load demand is way more complex and detailed. To examine the net present cost, the annual interest rate was considered to be 6%, and 25 years of project lifetime was also taken into account. Irrespective of the size or architecture of the whole power system, the capital and O&M cost was fixed as zero for this study. No capacity shortage penalty was contemplated.

## 4. Results and Analysis

### 4.1. Optimization Result

There were several constraints, including the annual maximum allowable capacity shortage and minimum renewable fraction, which were set to zero. The percentage of per hour load that would

be added to operating the reserve requirement was considered to be 10%. As for RE, the solar power would add half of the wind turbine output to the operating reserve, assuming the wind would have greater share of penetration. No minimum primary energy savings were taken into account.

All eight possible configurations, including the existing base case, were simulated and optimized by the HOMER software (Figure 6). It is evident from the results shown in Table 2 that the PV-wind-diesel-battery hybrid system is the most feasible system, having the lowest COE and NPC. This can also be seen in Figure 7.

In contrast, despite having the lowest initial capital cost, the diesel-only system seems to be the worst system in terms of the highest NPC and COE. This is because of the high consumption of fuel, as well as the high operation and maintenance costs associated with the generators. Replacement costs, which was the same as the initial capital cost for this system, is responsible for it as well.

**Table 2.** Comparison of various system architectures.

System Configuration	PV (kW)	Wind (kW)	Generator (kW)	Diesel (L/yr)	Battery (unit)	Converter (kW)	Initial Capital Cost (\$)	NPC (\$)	COE (\$/kW h)	RF (%)
Diesel only	-	-	730	392,706			131,468	4,430,795	0.340	-
PV-diesel	100	-	730	356,466	-	48	289,147	4,259,306	0.327	15
PV-diesel- battery	100	-	730		4	48	297,831	4,177,078	0.321	15
Wind-diesel	-	240	730	203,468	-	-	215,900	3,350,224	0.257	47
Wind -diesel- battery	-	240	730	271,544	4	24	224,584	3,290,681	0.253	47
Diesel-battery	-	-	730	383,414	4	24	152,584	4,353,627	0.334	-
PV-wind-diesel	100	240	730	252,523	-	48	361,147	3,271,915	0.251	56
PV-wind-diesel- battery	100	240	730	245,048	4	48	369,831	3,198,708	0.246	56

However, in other systems, the initial capital cost is higher compared to the diesel-only system due to the involvement of lots of (100 kW) PV panels and wind turbines (240 kW). The third-highest diesel consumption goes to the PV-diesel system. It can be noted that wind provides better renewable energy fraction (RF) than solar energy for all possible combinations. Thus, the wind-diesel system reduces the energy cost by more than 50% compared to the PV-diesel system. Again, since the wind-diesel system does not need a converter to do DC-AC or AC-DC operation, it plays a small role in achieving low COE and NPC as well. However, if the O & M cost increases for wind turbines, which is most likely due to the transportation cost to St. Martin's Island from the mainland, Chittagong, or Dhaka, the case would possibly be different. It is worth mentioning that HOMER used all three generators to optimize those systems and the best optimal case took the least capacity of generators to produce electricity.

Out of all eight cases, two cases were broadly analyzed by HOMER. The cases are the diesel-alone microgrid system, and the PV/Wind/Diesel/Battery Hybrid microgrid system.

Note that the first one is the base case, while the second case is the proposed power system for St. Martin's Island. Comparative, optimization, risk, and sensitivity analyses of these two cases would show the viability of employing the proposed system. Firstly, the optimization analysis is broadly discussed in the following sections.




Figure 6. Different combinations of architecture.




Figure 7. Variation of NPC of all configurations.

#### 4.1.1. Case 01: Diesel-Based Microgrid System

A base case with a "business as usual" approach was optimized to observe the technical, social, and economic performance of a diesel-only system without supplying energy storage or any other renewable energy sources. It is worth mentioning that currently, St. Martin's Island is operating using this scenario. In this case, three diesel generators were used, which were 500, 200, and 30 kW in size.

Table 3 indicates the optimized techno-economic simulation result of this system. It shows that the system has a total Net Present Cost (NPC) of \$4,430,795 and an operating cost of \$336,322 per year. HOMER estimated the levelized Cost of Energy (COE) of \$0.340 per kilowatt hour (kWh). This is around 27.40 Bangladesh taka (BDT) in Bangladeshi currency, which is quite close to what the island's people are currently paying.

Table 3. Augmented electrical and economic results of the base case.

	Generation Output			Total Gen
	Gen 500 (G1)	Gen 200 (G2)	Gen 30 (G3)	
Output (kWh/yr)	150,338	843,335	35,562	1,058,097
Output (%)	15	82	3	100
System parameters				
	AC load	Excess electricity	Unmet electric load	Capacity shortage
Output (kW)	1,019,080	10,153	0	88.4
%	100	3.8	0	0
System economics				
	Levelized COE (\$/kW h)	Total NPC (\$)	Operating cost (\$/yr)	Initial capital (\$)
	0.340	4,430,795.00	336,322	131,468

As the medium generator, G2 (200 kW) is mainly used to produce electricity, as the most substantial amount of NPC comes from it. From the optimization results, G2 had the most share in producing electricity for this specific system, scaling up to 82% of the total production, while G1


and G3 only contributed 15% and 3%, respectively. It is evident that G1 mainly serves at peak time, which is quite low at St. Martin's. However, note that the total electricity production is estimated at 1,029,234 kW/year.

Understanding how the system works requires a focus on how the generator operates. Obviously, G2 has the longest operating hours in a year-6472 h with a 48.1% capacity factor and \$15.7/hr fixed generation cost. G1 operates 646 h/year with a low capacity factor and high fixed generation cost due to its larger size, compared to G2. The marginal cost appears to be the same for all three generators. The rest of the operational specifications are pointed out in Table 4.


**Table 4.** Techno-economic operations of all diesel generators.

Electrical Variables	G1	G2	G3
Hours of operation (h/yr)	646	6,472	2,502
Capacity factor (%)	3.43	48.1	13.5
Mean electrical efficiency (%)	24.1	31	24.3
Fuel consumption (L/yr)	63,425	314,386	14,895
Fixed generation Cost (\$/h)	38	15.7	2.68
Marginal generation Cost (\$/kWh)	0.203	0.203	0.203


To have a closer look at how the system works, a sample week of January was simulated in HOMER. Figure 8 indicates the behavior of all three generators to cover up the electricity demand. Figure 9 shows the impact of Generators 1 and 2 on the AC primary load, while Figure 10 only considers the operational behavior of Generator 2.



**Figure 8.** Operational activities of all generators to meet the electricity demand in the first week of January.



**Figure 9.** Operational activities of Generators 1 and 2 to meet the electricity demand in the first week of January.



**Figure 10.** Operational activities of Generator 2 to meet the electricity demand in the first week of January.

It is clear from Figure 10 that Generator 2 almost meets all the demands for this case. Comparing Figures 9 and 10, it can be seen that the large 500 kW generator only covers the load when it increases over 190 kW for a few days at the start of a week. However, in that process, it produces practically all extra electricity of the all systems, resulting in high fuel consumption of the system, which ultimately leads to high operating costs. Moreover, Figure 8 shows the activities of all three generators to meet the load.

The electricity production by the generators per month for the existing diesel-alone system is indicated in Figure 11. It clearly shows the dominance of Generator 2 in supplying electricity to the plant.




Figure 11. Monthly average electricity production of diesel-only-based system.

#### 4.1.2. Case 02: PV-Wind-Battery-Diesel-based Hybrid Microgrid System

A PV-Wind-Battery-Diesel-based hybrid microgrid system was found to be the best way to address the ongoing electricity issues in St. Martin's Island, Bangladesh. In this case, two renewable energy resources (solar and wind) with a battery bank were considered to reduce the burden from the diesel generators and thus decrease the electricity price to a reasonable level. Table 5 summarises the optimization results.

Table 5. Techno-economic operations of PV-Wind-Battery-Diesel-based hybrid microgrid.

Generation Output							
	Gen 500	Gen 200	Gen 30	Wind Turbine	PV	Battery Annual Throughput	Total Gen
Output (kWh/yr)	35,995	511,262	25,932	578,005	160,860	87	1,312,141
% Output	3	39	2	44	12	-	100
System parameters							
	AC load	Surplus electricity	Unmet electric load	Capacity shortage			
Output (kW)	1,019,083	285,133	0	0			
% output	100	21.7	0.00229	0			
System economics							
Levelized COE (\$/kW h)	Total NPC (\$)	Operating cost (\$/yr)	Initial capital (\$)				
0.246	3,198,708	221,294	369,831				

Out of all eight possible systems, this hybrid system is best, mainly due to the reduction of cost of energy and NPC. The levelized COE reduced from \$0.340 to \$0.246, almost 28%, which is outstanding. The amount of NPC also came down by almost 28% compared to the base case. The 36% decrease of operation costs played a huge role in that. The operation cost was lower because the electricity contribution by the generators was lower (only 43%) when compared to the base case.

Table 5 demonstrates that wind technology contributes more than solar energy, leading by almost 27% of total electricity generation. Figure 12 also shows the supremacy of wind over solar power in terms of energy production. This is because of the high capital cost of PV panels, which makes them unsuitable to add a greater share of renewable energy despite the massive accessibility of solar radiation throughout the year. On the contrary, wind energy seems to be the best renewable energy resource, backing 44% of total energy production in this microgrid system. This is due to the decent wind speed during the summer season of Bangladesh, which stays from May to August, producing

more than 100 kW electricity in June and August, which can be seen in Figure 12. Note that wind power generation is lowest in November, followed by April and October. It can also be noted that wind energy has the lowest particular levelized COE compared to PV and Battery.





Figure 12. Monthly average electricity production of diesel-only-based system.

From Tables 5 and 6, it is evident that the generators show almost the same nature as the base case. The second generator has the most share (39% out of 44% diesel-based generation) among the three. It is worth mentioning that despite having the same marginal generation cost, the small and medium generators had a lower fixed generation cost. There is no unmet electricity in both cases, but in this system, excess electricity was produced almost 18% more. Taking a sample week of January, Figure 12 depicts that it is mostly due to wind energy penetration.

Table 6. Operation of different electrical variables for the hybrid system.

Electrical Variables	G1	G2	G3	Wind Turbine	PV	Battery
Hours of operation (h/yr)	159	5,649	2,086	7948	4,363	-
Capacity factor (%)	0.822	29.2	9.87	27.5	18.4	-
Mean electrical efficiency (%)	23.8	23.8	22.9	-	-	-
Fuel consumption (L/yr)	15,359	218,200	11,489	-	-	-
Fixed generation Cost (\$/h)	38	15.7	2.68	-	-	-
Marginal generation Cost(\$/kWh)	0.203	0.203	0.203	-	-	-
Levelized Cost (\$/kWh)	-	-	-	0.0172	0.0853	0.185

In Figure 13, the same month of January is simulated to see the operational activities of a 200 kW generator, like the one done in the base case in Figure 10. It seems that Generator 2 has a lesser number (46) of starts per year compared to the diesel-alone system. It was possible mainly due to the high availability of wind power.



**Figure 13.** Monthly average electricity production of diesel-only-based system.

#### 4.2. Sensitivity Analysis

It is highly recommended in a RE-based microgrid system to run a sensitivity analysis to observe the impact of several significant variables on the system's overall cost and feasibility. Generally, sensitivity analysis is done by changing the input variable to observe the behavioral change of the output closely. Normally, the impact on NPC gets priority in such kinds of analysis. In HOMER, there are several kinds of technical and economic input, and can be varied. There are a lot of variations in the focus area for doing the sensitivity analysis. Mainly, the sensitivity analysis is performed by seeing the effect of the following parameters on the already optimized results, which are acquired with the standard/current value of inputs: daily load demand; deferrable load; wind speed; solar energy (radiation); diesel price; several cost (capital, operating, replacement and O&M) inputs and cost multiplier; grid extension cost; annual interest rate; and maximum capacity shortage.

For the best optimal system, that is, a PV–Wind–battery–Diesel system, several variables are uncertain, considering the situation in St. Martin's. RE data taken from the satellite are not accurate enough. Instead, local ground data of the weather, measured for an extended period, is much appreciated, and an essential requirement for designing and analyzing any RE-based power system. To this intention, four of the most significant parameters, that is, diesel price, wind speed, solar radiation, and a primary load of the HOMER model were selected and varied 20% to 50% to see the change in outcome in relation to NPC and the levelized cost.

Before going to parameter-wise analysis, an overall sensitivity analysis was done to see how sensitive each variable was compared to others in terms of NPC (Figure 14). It clearly shows that diesel price has the most significant impact on NPC, followed by the total load demand change. Solar radiation has a very negligible influence on NPC of the hybrid renewable energy-based system. It also states that wind speed has a more significant effect on the system than solar radiation change; in other words, wind power contributes more than solar power.




Figure 14. Monthly average electricity production of diesel-only-based system.

4.2.1. Impact of Increase in Diesel Price

In the present situation in Bangladesh, there is no sign of a decrease in diesel prices. Hence, here, the diesel price was increased from \$0.81 to \$1.01 in steps of \$0.1.

The line graph of Figure 15 shows the behavior of NPC and COE when the value of variables is in the current state. It shows that COE increases at first, but starts to reduce when the load is increased by more than 2792 kWh per day. However, a further increase in diesel prices also increases the COE (Figures 16 and 17). It also shows that for only a \$0.001 increase in COE, there is an almost \$8000 increase in NPC. The diesel price has the most significant effect on COE. If it is increased from \$0.81 to \$1.01, the COE will increase from \$0.246 to \$0.294, resulting in an almost 19.5% escalation for every \$0.2 increase in the diesel price.




Figure 15. Line graph showing the characteristics of COE vs. NPC when the diesel price is \$0.81/L.




Figure 16. Line graph showing the characteristics of COE vs. NPC when the diesel price is \$0.91/L.




Figure 17. Line graph showing the characteristics of COE vs. NPC when the diesel price is \$1.01/L.

4.2.2. Impact of change in wind speed

The wind speed also played a vital role in determining the COE and NPC. By comparing Figures 18 and 19, it can be seen that an almost 20% increase of wind speed brings down almost 8% of COE, while NPC becomes lower by \$103,036. Wind turbine technology is not very familiar in Bangladesh compared to the PV panel. There is also a lack of skilled technicians and engineers. Also keeping in mind that those wind turbines and technologies are not the home product, Bangladesh will most likely have to hire experts from abroad to solve the issues related to wind turbines. Being an island, St. Martin’s is far from the mainland, which would also cause issues. All these factors will undoubtedly increase operation and maintenance costs. That is why the O&M cost increased up to two to four times in the sensitivity analysis (Figure 20). Results show that there is an almost \$30,680 and \$92,040 increase per year in TNPC if the O&M cost is raised by two and four times, respectively. COE also gets increased correspondingly. Figure 20 also reveals that the diesel price has the highest sensitivity, followed by the load and wind speed.




Figure 18. Line graph showing the characteristics of COE vs. NPC when the wind speed is 4 m/s.




Figure 19. Line graph showing the characteristics of COE vs. NPC when the wind speed is 5 m/s.




Figure 20. Spider graph presenting the effects of an O&M cost increase (two-fold) in total NPC.

#### 4.2.3. Impact of Change in Solar Radiation

In the case of a variation in solar radiation, it proves the optimization result that it has an almost negligible effect in the change of LCOE and NPC. Even with the 50% decrease and increase of solar

radiation in Figures 21 and 22, respectively, the COE changes to 1% and 2%. Thus, it is negligible for a 20% change concerning wind speed variation. The NPC also has an insignificant impact due to the change in solar radiation.




Figure 21. Line graph showing the characteristics of COE vs. NPC when the solar radiation is 4.05 kWh/m<sup>2</sup>/d.




Figure 22. Line graph showing the characteristics of COE vs. NPC when the solar radiation is 5.05 kWh/m<sup>2</sup>/d.

#### 4.2.4. Impact of Load Demand Increase

It is assumed that the load profile keeps being consistent over the system’s lifetime [42]. That is why it wants to simulate only one year of system action. However, there is extreme load demand in the hotels and resorts of St. Martin’s due to a large number of tourists throughout the year. Thus, a larger load demand plus lower power demand per day were analyzed by HOMER to see the deviation from the proposed system, especially regarding the change in NPC and COE.

If the load increases by 20%, the total NPC will also escalate by 30%. This is because the levelized COE falls by just 1.5% (indicated in Figure 23). An increase of around 24% in diesel fuel consumption is mainly responsible for this, which tips to a 22% rise in operational costs. It proves that diesel generators serve as the systems’ major spinning reserve producer. Thus, the authorities should consider this effect when designing this type of power system.

The LCOE also reduces due to the decrease in excess electricity by about 5%, from 21.7% to 16.1% when the largest load is considered. However, this is a small reduction compared to the effect

of a diesel price change. This indicates that wind turbines also serve the systems' spinning reserve, except their involvement is comparatively lower.




Figure 23. Effect of load demand increase on NPC and COE.

#### 4.3. Risk Analysis

There are no “risk-free” projects that exist in the world. Any new project or introduction of a new product needs a risk assessment to decide on capital investment since the profitability valuations form the project depends on the cash flow estimations, which are tentative. The cash flow depends on a few factors, like tax rate, life of the project, and the cost of all technology, including labor and O&M costs, which are uncertain. That is why the project analyst determines the risk considering a range of possible values of those factors.

Risk analysis can be done through the three most basic methods, namely, (a) sensitivity analysis, (b) break-even analysis, and (c) scenario analysis [43]. In this study, “scenario analysis” was adopted to assess the risk of St. Martin’s Hybrid microgrid project.

The scenario analysis includes the “base case scenario” analysis in comparison with the “best case scenario” and “worst case scenario” analysis. It detects the extreme and most likely project result. This study considered five important variables to analyze those cases.

According to a local study done several years back, it varies from 4.7 m/s to 5 m/s [44,45]. Solar radiation and wind speed varies  $\pm 100\%$ , while load demand changes by  $\pm 20\%$ . Diesel price and wind turbine O&M costs increase to 100% and four times, respectively, as there is no indication of a lower value in the near future. In HOMER, the variables mentioned in Table 7 are given as the input. It performed 2560 simulations and 600 sensitivity cases for those five sensitivity parameters. The selected optimization results are summarized below in Table 8.

Table 7. Values of five sensitive parameters for different cases.

Variables Considered	Best Case Scenario	Proposed Case Scenario	Worst Case Scenario	Comment
Load demand (kWh/day)	2234	2792	3350	$\pm 20\%$
Solar radiation (kWh/m <sup>2</sup> /day)	5.55	4.55	3.55	$\pm 100\%$
Wind speed (m/s)	5.72	4.72	3.72	$\pm 100\%$
Diesel Price (\$)	0.81	0.81	1.81	+100%
Wind turbine O&M cost (\$/year)	300	300	1200	+4 fold

**Table 8.** Scenario analysis of Hybrid PV/wind/battery/diesel system.

Parameters	Worst Case Scenario (WCS)	Proposed/Most likely Case Scenario (PCS)	Best Case Scenario (BCS)	Remarks	
				On BCS (Compared to PCS)	On WCS (Compared to PCS)
System Architecture	120kW PV, 03 Diesel generators, 04 Batteries, 08 wind turbine (240 kW) and 48 kW converter	100 kW PV, 03 diesel generators, 04 Batteries, 08 wind turbine (240 kW) and 48 kW converter	100kW PV, 02 Diesel generators, 04 Batteries, 08 wind turbine (240 kW) and 48 kW converter	500 kW generator is not used.	More 20 kW PV is required
Total Generation (kW)	1,346,996	1,312,141	1,355,085	42,944 more production	34,855 more production
Largest electricity producer	Gen 2 (48%)	Wind turbines (44%)	Wind turbines (61%)	17% more	4% more
Smallest electricity producer	Gen 3	Gen 3	Gen 3	2%	2%
AC load consumption (kWh/yr)	1,222,900	1,019,083	815,265	Less due to small daily demand	More due to higher daily demand
Excess Electricity	39.5%	21.7%	39.5%	17.8% added	8.43% reduced
Unmet electric load	0	0	0	None	None
Initial capital cost (\$)	396,331	369,831	288,362	23% less	7% added
Operating cost (\$)	387,617	221,294	151,341	33% reduction	43% addition
Levelized COE (\$)	0.342	0.246	0.213	\$0.033 less	\$0.096 more
Total NPC (\$)	5,351,381	3,198,708	2,223,005	31% less	40% extra
RE penetration	35%	56%	75%	Much better	Much lesser
CO <sub>2</sub> Emission (kg/year)	921,901	801,470	419,033	More than half reduced	13% increased

The comparative analysis of BCS and WCS corresponding to PCS was done in order to establish the viability of the proposed Hybrid PV/wind/battery/diesel system, which is represented in the remarks column. Clearly, there are significant changes, especially in terms of NPC, LCOE, operating cost, and CO<sub>2</sub> emission. Another noteworthy change in BCS is not considering the large 500 kW generator, while in WCS, 20 kW more PV capacity is added. Table 8 also indicates the percentage change in net present cost, operating cost, and levelized cost of energy of BCS is smaller than the WCS. This is because the diesel price and wind turbine cost are considered to be increased only. Figure 24 shows the graphical variation in a different set of costs for different scenarios.

Looking closely at the risky and advantageous situation after comparing both WCS and BCS to PCS, it is evident that NPC, LCOE, and operating cost WCS has more of an impact than BCS, which becomes risky. In contrast, for the initial capital cost, renewable energy penetration and reducing CO<sub>2</sub> emission BCS wins.

According to PDB, the tariff rate for the residential load of Bangladesh is about BDT 6.00. The load demand of the island's people is around 2792 kWh/day. If the government wants to electrify the whole area only by diesel generators, it would cost them about  $(2792 \text{ kWh/day} \times 27.2 \text{ BDT /kWh}) = \text{BDT } 75,942$  per day. However, for the proposed hybrid system, it would cost about  $(2792 \text{ kWh/day} \times \text{BDT } 19.68 \text{ /kWh}) = \text{BDT } 54,946$  per day. Thus, the government would lose around  $(75,942 - 54,946) = \text{BDT } 20,996$  every day and around BDT 7.7 million annually, which can be saved by implementing the proposed power system.




Figure 24. A variation in a different set of costs for three scenarios.

#### 4.4. Emission Analysis

According to the World Bank, Bangladesh is one of the most climate-prone areas. The emission of GHG is mainly responsible for this crisis. In 2012, USAID reported that Bangladesh had emitted 190 million metric tons (MtCO<sub>2</sub>e), with an energy sector contributing 33 percent to total emissions. The government of Bangladesh has undertaken several plans and actions, including 10 percent renewable energy delivery by 2020 and 15 percent GHG mitigation from the power, transportation, and energy-related industry sectors by 2030. In response to that, a hybrid renewable energy-based electricity system would certainly be a great achievement, which will ultimately play a vital role in easing the global warming condition. The annual emissions are determined from pollutant materials and gas, based on fuel consumption and fuel properties.

Table 9 displays the annual gas and other pollutant emissions from the optimized hybrid and the surviving conventional diesel-only power generation system in St. Martin's Island. These emitted gases or particles are the following: carbon dioxide (CO<sub>2</sub>), carbon monoxide (CO), unburned hydrocarbon (UHC), particulate matter (PM), sulfur dioxide (SO<sub>2</sub>), and finally, nitrogen oxide (NO<sub>x</sub>). The conventional diesel-based power system produces 1,034,123 kg/year of CO<sub>2</sub>, whereas the optimal hybrid renewable system configurations produce 801,470 kg/year CO<sub>2</sub>. From this table, we observed that a total of 23% of CO<sub>2</sub> emission could be prevented, resulting in around 232,653 kg/year less CO<sub>2</sub> emission by installing a hybrid renewable energy system arrangement on this island. However, in reality, due to the enormous usage of kerosene by ordinary people, the emission from the present case would be higher.

Table 9. Emission analysis of the pollutant materials.

Emitting Particle/gas	Optimized Case (kg/year)	Base Case (kg/year)	Less Emission (kg/year)
CO <sub>2</sub>	801,470	1,034,123	232,653
CO	1978	2553	575
Unburned hydrocarbons	219	283	64
Particulate matter	149	192	-
SO <sub>2</sub>	1609	2067	-
NO <sub>x</sub>	17,653	22,777	-

## 5. Conclusions

In this study, a techno-economic study of all possible hybrid microgrid systems and the existing base case has been executed with certain assumptions. The area considered in this study was St.

Martin’s Island. Using the HOMER simulation tool, the projections of accumulating a considerable segment of RE penetration were analyzed. To fill the research gap for a remote and sub-tropical island power system, optimization modeling supported by the comprehensive sensitivity and risk analyses were conducted to evaluate the technical, financial, as well as environmental benefits of the hybrid microgrid compared with the stand-alone, diesel-based configuration.

Results illustrate that:

(a) The diesel-alone existing power system is about 1.412 times more costly than a hybrid energy system in terms of the net present cost. This is mostly due to the present increasing diesel fuel rate.

(b) A 56% renewable energy penetration with a cost of energy of just \$0.246, that is, BDT 19.68 per unit (kWh) is possible through the proposed power system. In this way, COE lessens by almost by 28%, associated with the base case. Also, risk analysis shows that GoB can save around BDT 7.7 million annually, matched with the existing system.

(c) The economic superiority wind turbines over solar PV in St. Martin’s was established in this study.

(d) There is a chance of almost 23% reduction of CO<sub>2</sub>. Other pollutants like UHC and CO also emits less in the optimal system.

This study is anticipated to contribute to the “100% electrification plan” of “Vision 2021” of the government of Bangladesh, counting St. Martin’s island. It would also help “Bangladesh’s Intended Nationally Determined Contribution (INDC)” plan to reduce greenhouse gas emissions by 2030, delivering “green” technologies all over the country.

Furthermore, this study will inspire and motivate the government and other investors to invest here, knowing the situation of the people, and the technical and economic prospects of a RE-based hybrid microgrid system. It demonstrates the critical drivers for proposing and implementing such an electricity system in any remote area where the grid is not available. The researchers, industry authorities, and other concerned parties are expected to get insights from this local-oriented analysis, though further studies should consider other renewable energy sources, like biomass, to increase the cleaner energy penetration. Finally, it validates the cost-efficacy of the projected system and keeps the increasing rate of diesel prices in mind; it also exhibits the probability of the dipping diesel fuel dependence in Bangladesh’s electricity market.

**Author Contributions:** Conceptualization, H.M.; methodology, H.M.; software, H.M.; validation, H.M.; formal analysis, H.M.; resources, T.S.; writing—original draft preparation, H.M.; writing—review and editing, H.M., H.O.R.H., M.E.L., K.R.K., J.M.G.; supervision, T.S. All authors have read and agreed to the published version of the manuscript.

**Funding:** This research received no external funding.

**Conflicts of Interest:** The authors declare no conflict of interest.

## Abbreviations

The following abbreviations are used in this manuscript:

BBS	Bangladesh Bureau of Statistics
BCS	Best Case Scenario
BPC	Bangladesh Petroleum Corporation
HMPS	Hybrid Microgrid Power System
HOMER	Hybrid Optimization of Multiple Energy Resources
LCOE	Levelized Cost of Energy
LGED	Local Government Engineering Department
NPC	Net Present Cost
NREL	National Renewable Energy Laboratory
O&M	Operation and Maintenance
SHS	Solar Home System
PCS	Proposed Case Scenario
PDB	Power Development Board
PV	Photovoltaic
WCS	Worst Case Scenario

## References

1. St Martin's Island—Banglapedia. 2018. Available online: [http://en.banglapedia.org/index.php?title=St\\_Martin%27s\\_Island](http://en.banglapedia.org/index.php?title=St_Martin%27s_Island) (accessed on 12 January 2019).
2. Bangladesh Power Development Board. 2018. Available online: [https://www.bpdb.gov.bd/bpdb\\_new/](https://www.bpdb.gov.bd/bpdb_new/) (accessed on 1 January 2019).
3. Bangladesh Bureau of Statistics. 2018. Available online: <http://www.bbs.gov.bd/> (accessed on 10 January 2019).
4. Wouters, C. Towards a regulatory framework for microgrids—The Singapore experience. *Sustain. Cities Soc.* **2015**, *15*, 22–32. [CrossRef]
5. Saint Martin Island Map, 2020. Available online: [http://www.nktravelandtourism.com/stm\\_map.php](http://www.nktravelandtourism.com/stm_map.php) (accessed on 22 March 2020).
6. Sinha, S.; Chandel, S. Review of software tools for hybrid renewable energy systems. *Renew. Sustain. Energy Rev.* **2014**, *32*, 192–205. [CrossRef]
7. Groppi, D.; Astiaso Garcia, D.; Lo Basso, G.; Cumo, F.; De Santoli, L. Analysing economic and environmental sustainability related to the use of battery and hydrogen energy storages for increasing the energy independence of small islands. *Energy Convers. Manage.* **2018**, *177*, 64–76. [CrossRef]
8. Dominković, D.F.; Stark, G.; Hodge, B.M.; Pedersen, A.S. Integrated Energy Planning with a High Share of Variable Renewable Energy Sources for a Caribbean Island. *Energies* **2018**, *11*, 2193. [CrossRef]
9. Li, C.; Ge, X.; Zheng, Y.; Xu, C.; Ren, Y.; Song, C.; Yang, C. Techno-economic feasibility study of autonomous hybrid wind/PV/battery power system for a household in Urumqi, China. *Energy* **2013**, *55*, 263–272. [CrossRef]
10. Al-Karaghoul, A.; Kazmerski, L.L. Optimization and life-cycle cost of health clinic PV system for a rural area in southern Iraq using HOMER software. *Sol. Energy* **2010**, *84*, 710–714. [CrossRef]
11. Abdilahi, A.M.; Yatim, A.H.M.; Mustafa, M.W.; Khalaf, O.T.; Shumran, A.F.; Nor, F.M. Feasibility study of renewable energy-based microgrid system in Somaliland's urban centers. *Renew. Sustain. Energy Rev.* **2014**, *40*, 1048–1059. [CrossRef]
12. Olatomiwa, L. Optimal configuration assessments of hybrid renewable power supply for rural healthcare facilities. *Energy Rep.* **2016**, *2*, 141–146. [CrossRef]
13. Rehman, S.; Al-Hadhrani, L.M. Study of a solar PV–diesel–battery hybrid power system for a remotely located population near Rafha, Saudi Arabia. *Energy* **2010**, *35*, 4986–4995. [CrossRef]
14. Tayyab, M.; Zubair, M. PV-solar/Wind Hybrid Energy System for GSM/CDMA Type Mobile Telephony Base Station. *Int. J. Eng. Res. Appl.* **2015**, *5*, 74–79.
15. Akella, A.; Sharma, M.; Saini, R. Optimum utilization of renewable energy sources in a remote area. *Renew. Sustain. Energy Rev.* **2007**, *11*, 894–908. [CrossRef]
16. Kumaravel, S.; Ashok, S. An optimal stand-alone biomass/solar-PV/pico-hydel hybrid energy system for remote rural area electrification of isolated village in Western-Ghats region of India. *Int. J. Green Energy* **2012**, *9*, 398–408. [CrossRef]
17. Zoulias, E.; Lymberopoulos, N. Techno-economic analysis of the integration of hydrogen energy technologies in renewable energy-based stand-alone power systems. *Renew. Energy* **2007**, *32*, 680–696. [CrossRef]
18. Mohamed, A.; Khatib, T. Optimal sizing of a PV/wind/diesel hybrid energy system for Malaysia. In Proceedings of the 2013 IEEE International Conference on Industrial Technology (ICIT), Cape Town, South Africa, 25–28 February 2013; pp. 752–757.
19. Masrur, H.; Khan, K.R.; Abumelha, W.; Senjyu, T. Efficient Energy Delivery System of the CHP-PV-based Microgrids with the Economic Feasibility Study. *Int. J. Emerg. Electr. Power Syst.* **2020**, *21*, ijjeeps-2019-0144. [CrossRef]
20. Rajkumar, R.; Ramachandramurthy, V.K.; Yong, B.; Chia, D. Techno-economical optimization of hybrid pv/wind/battery system using Neuro-Fuzzy. *Energy* **2011**, *36*, 5148–5153. [CrossRef]
21. Diaf, S.; Diaf, D.; Belhamel, M.; Haddadi, M.; Louche, A. A methodology for optimal sizing of autonomous hybrid PV/wind system. *Energy Policy* **2007**, *35*, 5708–5718. [CrossRef]
22. Ekren, O.; Ekren, B.Y.; Ozerdem, B. Break-even analysis and size optimization of a PV/wind hybrid energy conversion system with battery storage—A case study. *Appl. Energy* **2009**, *86*, 1043–1054. [CrossRef]

23. Maouedj, R.; Mammeri, A.; Draou, M.; Benyoucef, B. Performance evaluation of hybrid photovoltaic-wind power systems. *Energy Procedia* **2014**, *50*, 797–807. [CrossRef]
24. Bekele, G.; Palm, B. Feasibility study for a standalone solar–wind-based hybrid energy system for application in Ethiopia. *Appl. Energy* **2010**, *87*, 487–495. [CrossRef]
25. Ashourian, M.; Cherati, S.; Zin, A.M.; Niknam, N.; Mokhtar, A.; Anwari, M. Optimal green energy management for island resorts in Malaysia. *Renew. Energy* **2013**, *51*, 36–45. [CrossRef]
26. Dahiru, A.T.; Tan, C.W. Optimal sizing and techno-economic analysis of grid-connected nanogrid for tropical climates of the Savannah. *Sustain. Cities Soc.* **2020**, *52*, 101824. [CrossRef]
27. Kumar, J.; Suryakiran, B.V.; Verma, A.; Bhatti, T.S. Analysis of techno-economic viability with demand response strategy of a grid-connected microgrid model for enhanced rural electrification in Uttar Pradesh state, India. *Energy* **2019**, *178*, 176–185. [CrossRef]
28. Kasaeian, A.; Rahdan, P.; Rad, M.A.V.; Yan, W.M. Optimal design and technical analysis of a grid-connected hybrid photovoltaic/diesel/biogas under different economic conditions: A case study. *Energy Convers. Manag.* **2019**, *198*, 111810. [CrossRef]
29. Li, C.; Zhou, D.; Zheng, Y. Techno-economic comparative study of grid-connected PV power systems in five climate zones, China. *Energy* **2018**, *165*, 1352–1369. [CrossRef]
30. Islam, M.S. A techno-economic feasibility analysis of hybrid renewable energy supply options for a grid-connected large office building in southeastern part of France. *Sustain. Cities Soc.* **2018**, *38*, 492–508. [CrossRef]
31. Alharthi, Y.Z.; Siddiki, M.K.; Chaudhry, G.M. Resource Assessment and Techno-Economic Analysis of a Grid-Connected Solar PV-Wind Hybrid System for Different Locations in Saudi Arabia. *Sustainability* **2018**, *10*, 3690. [CrossRef]
32. Maleki, A.; Rosen, M.A.; Pourfayaz, F. Optimal Operation of a Grid-Connected Hybrid Renewable Energy System for Residential Applications. *Sustainability* **2017**, *9*, 1314. [CrossRef]
33. Nacer, T.; Hamidat, A.; Nadjemi, O. Techno-economic Impacts Analysis of a Hybrid Grid Connected Energy System Applied for a Cattle Farm. *Energy Procedia* **2015**, *75*, 963–968. [CrossRef]
34. NREL: Bangladesh Data. Available online: <https://maps.nrel.gov/rede-bangladesh/> (accessed on 10 January 2019).
35. Bangladesh Petroleum Corporation (BPC). 2019. Available online: <http://www.bpc.gov.bd/site/view/policies> (accessed on 10 February 2019).
36. Suntech. 2019. Available online: <http://www.suntech-power.com> (accessed on 10 October 2019).
37. Tokai Power Products Ltd. 2019. Available online: <https://www.tokaipower.com> (accessed on 10 February 2019).
38. Power Converters and Inverters:ABB. 2019. Available online: <https://new.abb.com/power-converters-inverters> (accessed on 10 October 2019).
39. Fuhrlaender Wind Turbine. 2019. Available online: <https://en.wind-turbine-models.com/turbines/278-fuhrlaender-fl-30#datasheet> (accessed on 10 March 2019).
40. Batteries. 2019. Available online: <https://www.rollsbattery.com/catalog> (accessed on 10 October 2019).
41. Grameen Shakti. Available online: <http://www.gshakti.org/> (accessed on 8 December 2018).
42. Lambert, T.; Gilman, P.; Lilienthal, P. *Micropower System Modeling with Homer*; Wiley Online Library: Hoboken, NJ, USA, 2006; pp. 379–418. [CrossRef]
43. Park, C.S.; Kim, G.; Choi, S. *Engineering Economics*; Prentice Hall: Upper Saddle River, NJ, USA, 2007; Volume 22.
44. Islam, A.K.M.S.; Rahman, Md.M.; Mondal, Md.A.H.; Alam, F. Hybrid energy system for St. Martin Island, Bangladesh: An optimized model. *Procedia Eng.* **2012**, *49*, 179–188. [CrossRef]
45. Solar and Wind Energy Resource Assessment (SWERA) Report. 2019. Available online: [https://openei.org/wiki/Solar\\_and\\_Wind\\_Energy\\_Resource\\_Assessment\\_\(SWERA\)](https://openei.org/wiki/Solar_and_Wind_Energy_Resource_Assessment_(SWERA)) (accessed on 9 October 2019).

